

Consultation Response from: KC Environmental Health (Pollution & Noise Control)		
2023/90216 adj, 17, Hillhouse Lane, Fartown, Huddersfield, HD1 6EF		
Discharge condition 15 (extract ventilation system) on previous permission 2019/93483 for erection of 4 A1/A3 ground floor units, 3 B1 offices and ancillary space, free standing ATM and car park		
Date Responded: 5th April 2023	Responding Officer: RM	Responding Ref: WK/202307744
To discharge condition 15 a drawing titled Mechanical Services Kitchen Ventilation Layout (drawing no. M001) (dated: Jan 23) by Shearstone Mechanical Building Services Consultancy has been submitted. The drawing and annotation describe in detail the proposed kitchen ventilation system which is to consist of: a kitchen canopy, pre-filters, electrostatic precipitator, bifurcated extract fan, outside noise attenuators and a high velocity roof cowl which is to terminate 1m above the apex of the roof. We accept the proposed ventilation system and make the following recommendations. Recommendation We accept the proposed kitchen ventilation system as detailed in drawing no M001 (dated Jan 23) by Shearstone Mechanical Building Services Consultancy but recommend that Condition 15 can not be fully discharged until the kitchen ventilation system has been installed and is fully operational.		