

Consultation Response from: KC Environmental Health (Pollution & Noise Control)		
2023/90358 - Shepley Spring, The Knowle, Shepley, Huddersfield, HD8 8EA		
Erection of substations and associated external plant		
Responding Date: 26 April 2023	Responding Officer: Mohammed Nasim	Responding Ref: WK202312304
<u>Comments</u> <u>Noise</u> In our comments dated 22 March 2023, we recommended a condition for a Noise Impact Assessment to be submitted. The applicant has responded via an e-mail dated 20 April 2023 to state that feedback from the transformer manufacturer indicates that the output, enclosure and distance to residential properties indicate there will not be an issue with noise. This is accepted but a compliance condition is recommended to ensure any noise does not exceed the existing background level. <u>Contaminated Land</u> Our comments and recommended conditions dated 22 March 2023 remain. <u>Recommended Conditions</u> NC10 Noise from Fixed Plant & Equipment - Condition The combined noise from any fixed mechanical services and external plant and equipment shall be effectively controlled so that the combined rating level of noise from all such equipment does not exceed the background sound level at any time. 'Rating level' and 'background sound level' are as defined in BS 4142:2014+A1:2019. Reason: To ensure the proposed development does not cause harmful noise pollution within neighbouring noise sensitive locations, in the interest of amenity, to comply with the aims and objectives of Policies LP24 and LP52 of the Kirklees Local Plan and Chapters 12 and 15 of the National Planning Policy Framework.		