



The Coal
Authority



INVESTOR IN PEOPLE



RTPI
Learning Partner

200 Lichfield Lane
Berry Hill
Mansfield
Nottinghamshire
NG18 4RG

Tel: 01623 637 119 (Planning Enquiries)

Email: planningconsultation@coal.gov.uk

Web: www.gov.uk/coalauthority

For the Attention of: Richard A Gilbert – Case Officer
Kirklees Council

[By Email: DC.Admin@kirklees.gov.uk]

4 April 2023

Dear Richard

PLANNING APPLICATION: 2023/62/90668/E

Erection of B2/B8 industrial unit and associated works; Grange Moor Coachworks, Barnsley Road, Grange Moor, Huddersfield, WF4 4DR

Thank you for your consultation letter of 16 March 2023 seeking the views of the Coal Authority on the above planning application.

The Coal Authority is a non-departmental public body sponsored by the Department for Energy Security and Net Zero. As a statutory consultee, the Coal Authority has a duty to respond to planning applications and development plans in order to protect the public and the environment in mining areas.

The Coal Authority Response: Material Consideration

I have reviewed the proposals and confirm that the application site falls within the defined Development High Risk Area; therefore within the application site and surrounding area there are coal mining features and hazards which need to be considered in relation to the determination of this planning application.

The Coal Authority's information indicates that the site lies in an area of actual shallow coal mine workings. Voids and broken ground associated with such workings can pose a risk of ground instability and may give rise to the emission of mine gases.

In addition to the above, our records indicate the presence of one recorded mine entry (shaft) within the planning boundary. An untreated mine entry and its resultant zone of influence pose a significant risk not only to surface stability but also public safety.

The Coal Authority notes the submitted Phase 1 Environmental Desk Study & Coal Mining Risk Assessment (16 January 2022 prepared by RGS Ltd), which accompanies the application and which recommends the investigation of potential shallow coal mine workings to identify any necessary remedial measures. In terms of the risks posed by the mine entry, whilst the report confirms it has no stability implications on the proposed building due to its distance away, the report does recommend its investigation. This is further reinforced when considering the proposed water attenuation feature, which is proposed to channel water into the existing pond within close proximity of the recorded mine entry, which the report does not appear to consider.

The intrusive site investigations should be designed and undertaken by competent persons and should be appropriate to assess the ground conditions on the site in order to establish the coal-mining legacy present and the risks it may pose to the development and inform any remedial works and/or mitigation measures that may be necessary.

The applicant should note that Permission is required from the Coal Authority Permit and Licensing Team before undertaking any activity, such as ground investigation and ground works, which may disturb coal property. Please note that any comments that the Coal Authority may have made in a Planning context are without prejudice to the outcomes of a Permit application.

Mine Gas

It should be noted that wherever coal resources or coal mine features exist at shallow depth or at the surface, there is the potential for mine gases to exist. These risks should always be considered by the LPA. The Planning & Development team at the Coal Authority, in its role of statutory consultee in the planning process, only comments on gas issues if our data indicates that gas emissions have been recorded on the site. However, the absence of such a comment should not be interpreted to imply that there are no gas risks present. Whether or not specific emissions have been noted by the Coal Authority, local planning authorities should seek their own technical advice on.

SUDS

It should be noted that where SUDs are proposed as part of the development scheme consideration will need to be given to the implications of this in relation to the stability and public safety risks posed by coal mining legacy. The developer should seek their own advice from a technically competent person to ensure that a proper assessment has been made of the potential interaction between hydrology, the proposed drainage system and ground stability, including the implications this may have for any mine workings which may be present beneath the site.

The Coal Authority Recommendation to the LPA

The Coal Authority concurs with the recommendations of the Phase 1 Environmental Desk Study & Coal Mining Risk Assessment; that shallow coal mine workings and a recorded mine entry pose a risk to the proposed development and that intrusive site investigation works should be undertaken prior to development.

Accordingly, the Coal Authority recommends the imposition of the following conditions:

1. *No development shall commence until;*

a) a scheme of intrusive investigations has been carried out on site to establish the risks posed to the development by coal mining legacy;

b) any remediation works and/or mitigation measures to address the coal mining legacy features, as may be necessary, have been implemented on site in full in order to ensure that the site is safe and stable for the development proposed.

The intrusive site investigations and remedial works shall be carried out in accordance with authoritative UK guidance.

2. *Prior to the occupation of the development, or it being taken into beneficial use, a signed statement or declaration prepared by a suitably competent person confirming that the site is, or has been made, safe and stable for the approved development shall be submitted to the Local Planning Authority for approval in writing. This document shall confirm the methods and findings of the intrusive site investigations and the completion of any remedial works and/or mitigation necessary to address the risks posed by both the recorded mine entries and the shallow coal mine workings .*

The Coal Authority therefore **has no objection** to the proposed development **subject to the imposition of the conditions to secure the above**. *This is our recommendation for condition wording. Whilst we appreciate that you may wish to make some amendment to the choice of words, we would respectfully request that the specific parameters to be satisfied are not altered by any changes that may be made.*

The following statement provides the justification why the Coal Authority considers that a pre-commencement condition is required in this instance:

The undertaking of intrusive site investigations, prior to the commencement of development, is considered to be necessary to ensure that adequate information pertaining to ground conditions and coal mining legacy is available to enable appropriate remedial and mitigatory measures to be identified and carried out before building works commence on site. This is in order to ensure the safety and stability of the development, in accordance with paragraphs 183 and 184 of the National Planning Policy Framework.

Please do not hesitate to contact me if you would like to discuss this matter further.

Yours sincerely

Chris MacArthur *B.Sc.(Hons), DipTP, MRTPI*
Planning Liaison Manager

General Information for the Applicant

Under the Coal Industry Act 1994 any intrusive activities, including initial site investigation boreholes, and/or any subsequent treatment of coal mine workings/coal mine entries for ground stability purposes require the prior written permission of The Coal Authority, since such activities can have serious public health and safety implications. Failure to obtain permission will result in trespass, with the potential for court action. In the event that you are proposing to undertake such work in the Forest of Dean local authority area our permission may not be required; it is recommended that you check with us prior to commencing any works. Application forms for Coal Authority permission and further guidance can be obtained from The Coal Authority's website at:

<https://www.gov.uk/get-a-permit-to-deal-with-a-coal-mine-on-your-property>

Building over or within the influencing distance of a mine entry (shaft or adit) can be dangerous and has the potential for significant risks to both the development and the occupiers if not undertaken appropriately. The Coal Authority would draw your attention to our adopted policy regarding new development and mine entries:

<https://www.gov.uk/government/publications/building-on-or-within-the-influencing-distance-of-mine-entries>

Disclaimer

The above consultation response is provided by The Coal Authority as a Statutory Consultee and is based upon the latest available data on the date of the response, and electronic consultation records held by The Coal Authority since 1 April 2013. The comments made are also based upon only the information provided to The Coal Authority by the Local Planning Authority and/or has been published on the Council's website for consultation purposes in relation to this specific planning application. The views and conclusions contained in this response may be subject to review and amendment by The Coal Authority if additional or new data/information (such as a revised Coal Mining Risk Assessment) is provided by the Local Planning Authority or the Applicant for consultation purposes.

In formulating this response The Coal Authority has taken full account of the professional conclusions reached by the competent person who has prepared the Coal Mining Risk Assessment or other similar report. In the event that any future claim for liability arises in relation to this development The Coal Authority will take full account of the views, conclusions and mitigation previously expressed by the professional advisers for this development in relation to ground conditions and the acceptability of development.