

Subject: RE: Attached letter from Kirklees Council regarding application number 2023/90773 at location Land at, Penistone Road, Fenay Bridge, Huddersfield, HD8 0AW
Date: 22 March 2023 17:42:51

I would like to advise that structures conditions (8 & 9) can not be discharged subject to the satisfactory resolution of the following requirement:

1. Condition 8 – This will require the formal technical approval (via the submission of AIPs) for the design of all proposed retaining walls adjacent to the new highway including any modification to the existing highway retaining wall supporting the A629 Penistone Road, as stated in <https://www.kirklees.gov.uk/beta/regeneration-and-development/pdf/highways-structural-procedures.pdf>.
2. Condition 9 – This will require the submission of detailed and fully dimensioned X-sectional details so as to determine whether the design of proposed culvert headwalls on the A629 Penistone will be liable to a formal technical approval, as stated in (1) above. In addition, the design of all oversize PCC manholes (ID> 900mm) will be liable to approval via certification, as stated in <https://www.kirklees.gov.uk/beta/regeneration-and-development/pdf/highways-structural-procedures.pdf>.

Regards

Farhad Khatibi

Bridges & Structures Manager
Structures Section
Highways and Streetscene
Kirklees Council

Highways and Streetscene | Highways Structures | PO Box 1720 | Huddersfield | HD1 6EL

☎ **External:** 01484 221000 **Internal:** 74199
Mobile: None
✉ **Email:** farhad.khatibi@kirklees.gov.uk

