

**Subject:** FW: Fw: 2023/91032 - 12 Highroyd, Lepton, Huddersfield, HD8 0EB  
**Date:** 04 July 2023 11:41:04

---

Further to our previous consultation responses, we have now met the applicant on site and carried out some survey work. We now believe that the culvert shown on our plans is only guess as to where a culvert may have run between open sections of watercourse on historical plans. It seems almost certain as the area was development that any flows were intercepted into a new surface water public sewer which is also shown through the property. This has been surveyed and is clear of the extension proposed.

We therefore can remove our objection to the application. Yorkshire Water may wish to comment separately.

Kind regards,

Paul Farndale  
Kirklees LLFA

---