

Consultation Response from Strategic Waste

33 Alder St, Fartown, Huddersfield HD1 6LD

Erection of 2 storey building, Ground floor café and first floor office

Date Response 07.07.23

Responding Officer WT

REF 2023/91071

There is one closed landfill site within 250m of application address.

SW0002 (Brick and Tile) lies approximately 190m away, there has been no CH4 detected over the last 18 years, CO2 has ranged between 2% and 12% v/v over the same time period.

**Wayne Thornton
Monitoring Officer
REF WT3728**