

Consultation Response from: KC Environmental Health (Pollution & Noise Control)		
2023/90792 - Land Adjacent To 6 Sands Terrace, Leeds Road, Huddersfield, HD2 1YX		
Erection of two-storey workshop (Class E (g)) and associated works		
Responding Date: 15 May 2023	Responding Officer: Mohammed Nasim	Responding Ref: WK202313125
<p><u>Comments</u></p> <p><u>Noise</u> The proposal is for a workshop within an existing mixed commercial/industrial/residential area. The submitted Design and Access Statement from Broadgrove dated March 2021 Ref 151/001 outlines the surrounding area and discusses the impact of noise on the amenity of the occupiers of Sands Terrace. We would look to control any impact of noise on residential amenity and recommend a condition for any fixed mechanical plant to not exceed the background levels and also to control the hours of use.</p> <p>The construction hours for the development will need to be controlled to prevent any loss of amenity during this phase.</p> <p><u>Contaminated Land</u> This site has been identified on our mapping system as being adjacent to potentially contaminated land (our map ref 67/10). Contaminated land conditions are therefore necessary.</p> <p><u>Electric Vehicle Charging Points</u> There is to be parking for 4 vehicles on the site. In an application of this nature, it is expected that facilities for charging electric vehicles and other ultra-low emission vehicles are provided in accordance with the National Planning Policy Framework and <i>Air Quality & Emissions Technical Planning Guidance</i> from the West Yorkshire Low Emissions Strategy Group. A condition requiring charging points is therefore necessary.</p> <p><u>Recommended Conditions</u></p> <p>NC10 Noise from Fixed Plant & Equipment - Condition The combined noise from any fixed mechanical services and external plant and equipment shall be effectively controlled so that the combined rating level of noise from all such equipment does not exceed the background sound level at any time. 'Rating level' and 'background sound level' are as defined in BS 4142:2014+A1:2019. Reason: To ensure the proposed development does not cause harmful noise pollution within neighbouring noise sensitive locations, in the interest of amenity, to comply with the aims and objectives of Policies LP24 and LP52 of the Kirklees Local Plan and Chapters 12 and 15 of the National Planning Policy Framework.</p> <p>HUC4 Hours of Use combined Open for Customers, Deliveries and Dispatches – Condition The use hereby permitted shall not be open to customers outside the hours of:</p>		

- 0800hrs to 1800hrs Monday to Friday, and
- 0800hrs to 1600hrs Saturday

Reason: To ensure that the proposed use(s) does not give rise to the loss of amenity to nearby residential properties, by reason of noise or disturbance at unsociable hours, to accord with the aims of Policies LP24 and LP52 of the Kirklees Local Plan and Chapters 12 and 15 of the National Planning Policy Framework.

CLC6 Reporting of Unexpected Contamination - Condition

In the event that contamination, or the presence of coal not previously identified by the developer prior to the grant of this planning permission is encountered during the development, all groundworks in the affected area (except for site investigation works) shall cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Groundworks in the affected area shall not recommence until either (a) a Remediation Strategy by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority or (b) the Local Planning Authority has confirmed in writing that remediation measures are not required. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures. Thereafter remediation of the site shall be carried out and completed in accordance with the approved Remediation Strategy.

Following completion of any measures identified in the approved Remediation Strategy a Verification Report shall be submitted to the Local Planning Authority. No part of the site shall be brought into use until such time as that part of the site has been remediated in accordance with the approved Remediation Strategy and a Verification Report in respect of those works has been approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 183 and 184 of the National Planning Policy Framework.

CLC7 Contaminated land - Footnote

All contamination reports shall be prepared by a suitably competent person, as defined in Annex 2 of the National Planning Policy Framework 2021. Reports must be prepared in accordance with the following guidance:

- *Land Contamination Risk Management (LCRM)*
- *BS 10175:2011+ A2:2017 Investigation of Potentially Contaminated Sites. Code of Practice*
- *Development on Land Affected by Contamination - Technical Guidance for Developers, Landowners & Consultants - (v11.2) June 2020 by the Yorkshire and Lincolnshire Pollution Advisory Group.*

EVC1 Electric Vehicle Charging Points - Condition

Before the electrical system is installed, a scheme detailing the dedicated facilities that will be provided for charging electric vehicles and other ultra-low emission vehicles shall be submitted to and approved in writing by the Local Planning Authority. The scheme shall meet at least the following minimum standard for numbers and power output:

- One Standard Electric Vehicle Charging Point providing a continuous supply of at least 16A (3.5kW) for at least 10% of non-residential parking spaces

- For developments where some or all of the parking is likely to be used for shorter stay parking (30mins to 4 hours), Fast (7-23kW) or Rapid (43kW+) charging points will be more appropriate. If Fast or Rapid charging points are proposed together with restrictions on the times that vehicles are allowed to be parked at these points, then a lower number of charging points may be acceptable.

The agreed dedicated facilities for charging electric vehicles are to be installed, maintained and retained thereafter.

Reason: In the interest of supporting and encouraging low emission vehicles, in the interest of air quality enhancement, to comply with the aims and objectives of Policies LP20, LP24 and LP47 of the Kirklees Local Plan, Chapters 2, 9 and 15 of the National Planning Policy Framework and the West Yorkshire Low Emission Strategy (WYLES).

EVF1 Electric Vehicle Charging Points – Footnote

- A Standard Electric Vehicle Charging Point is one which is capable of providing a continuous supply of at least 16A (3.5kW) and up to 32A (7kW). The higher output is more likely to be futureproof.
- At non-residential developments, the requirement for one standard electric vehicle charging point for at least 10% of parking spaces may initially be reduced to one charging point for at least 5% of parking spaces with the remainder provided at an agreed trigger point.
- For developments where some or all of the parking is likely to be used for shorter stay parking (30mins to 4 hours), Fast (7-23kW) or Rapid (43kW+) charging points will be more appropriate. If Fast or Rapid charging points are proposed together with restrictions on the times that vehicles are allowed to be parked at these points, then a lower number of charging points may be acceptable.
- The electrical supply of the final installation should allow the charging equipment to operate at full rated capacity and the installation must comply with all applicable electrical requirements in force at the time of installation.

CSC1 Construction Site Working Times - Condition

Noise from any construction related activities shall not be audible outside the site boundary outside the hours of:

- 07.30 to 18.30 hours Mondays to Fridays
- 08.00 to 13.00 hours, Saturdays

Noise from any construction related activities shall not be audible outside the site boundary at any time on Sundays or Public Holidays.

Reason: To safeguard the amenities of the occupiers of nearby properties in accordance with part 15 of the NPPF and LP52 of the Local Plan

CSF1 Construction Sites working times – Footnote

Kirklees Council has powers under Section 60 of the Control of Pollution Act 1974 to control noise from construction sites and may serve a notice imposing requirements on the way in which construction works are to be carried out. It has additional powers under Sections 80 of the Environmental Protection Act 1990 to prevent statutory nuisance including noise, dust, smoke and artificial light and must serve an abatement notice when it is satisfied that a statutory nuisance exists or is likely to occur or recur. Failure to comply with a notice served

using the above-mentioned legislation would be an offence for which the maximum fine on summary conviction is unlimited.