

Consultation Response from: KC Environmental Health (Pollution & Noise Control)

2023/91107 The Wheatsheaf, 95, Gomersal Lane, Gomersal, Cleckheaton, BD19 4JQ

Advertisement Consent for installation of illuminated and non-illuminated signs

Date Responded:
25th April 2023

Responding Officer:
RM

Responding Ref:
WK/202312202

The application is for several illuminated and non-illuminated signs which appear to replace existing signs. All the signs are less than 10m² with an illuminance of 200cd/m² which is in accordance with the Institute of Lighting Professionals (ILP) guidance. We note that the proposal also includes 6 floodlights. We accept the information that has been provided and would remind the applicant that the floodlights must be angled towards the building to prevent light spillage and nuisance to nearby properties. All signs should only be operational during trading hours. We therefore have no objections to permission being granted for this development.

We would remind that applicant that the Local Authority has powers under Sections 80 of the Environmental Protection Act 1990 to prevent statutory nuisance including artificial light and must serve an abatement notice when it is satisfied that a statutory nuisance exists or is likely to occur or recur. Failure to comply with a notice served using the above-mentioned legislation would be an offence for which the maximum fine on summary conviction is unlimited.