

| | | |
|---|---|--|
| Consultation Response from: KC Environmental Health (Pollution & Noise Control) | | |
| 2023/91210 - Thornton And Ross Ltd, Manchester Road, Linthwaite, Huddersfield, HD7 5QH | | |
| Discharge condition 6 (noise barriers), 7 (finishes colour of plant and dimensions of pump and chiller) on previous permission 2021/92779 for erection of plant deck consisting of new heating, ventilation and air conditioning system (HVAC) with associated works | | |
| Responding Date: 10 May 2023 | Responding Officer: Mohammed Nasim | Responding Ref: WK202312168 |
| <u>Note</u> – These comments relate to Condition 6 (Noise Barriers) ONLY | | |
| <p><u>Comments</u></p> <p>In our comments dated 10 December 2021 (submitted under 2021/92779), we accepted the findings of the Noise Impact Assessment (NIA) authored by RPS dated 07 July 2021 Ref JAJ02698-REPT-01-R1. However, as there was some uncertainty in the final installation of mechanical plant and its respective attenuation, we requested an addendum report be submitted once details of the mechanical plant were finalised.</p> <p>In support of this application to discharge the condition, the applicant has submitted a Noise Impact Assessment authored by RPS dated 06 July 2021 Ref JAJ02698-REPT-01-R0 and it is noted that this NIA predates the one submitted under 2021/92779. It is therefore rejected.</p> <p>The applicant is advised to submit an up to date NIA to take into account the uncertainty within the Noise Impact Assessment dated 07 July 2021 Ref JAJ02698-REPT-01-R1.</p> <p><u>Recommendations</u></p> <p>We recommend condition 6 is not discharged at this time.</p> | | |