

**Consultation Response from KC,
Lead Local Flood Authority**

2023/91236 White Syke Farm, Marsden Lane, Marsden, Huddersfield, HD7 6AF

Erection of lean-to car port to western gable end (Listed Building)

Date Responded: 15/06/2023.

Responding Officer: Martin Stephenson

Responding Ref: 0

Documents reviewed by the LLFA:

Melanie Parkin:

- Drawing Ref: White Sykes Farm – Site Plan – Proposed Car Port dated 04/05/2023.

Drainage Summary:

The proposed car port appears to be more than 3.0m from the centreline of the culvert (the minimum easement requirement) serving the aqueduct. Therefore the LLFA confirms that there is no objection to the proposed development.

Kirklees Flood Management and Drainage as the Lead Local Flood Authority, SUPPORTS this application and has no recommended drainage conditions.