

**Consultation Response from KC,
Lead Local Flood Authority**

2023/91280 Bromley Farm Quarry, Barnsley Road, Upper Cumberworth, Huddersfield, HD8 8PD

Extension to previous Bromley Farm Quarry for extraction of clay, shale and incidental coal

Date Responded: 5th July 2023

Responding Officer: Paul Farndale

Responding Ref:

Kirklees Flood Management & Drainage acting as Lead Local Flood Authority can SUPPORT this application subject to the following condition.

DR04/5 (Amended) Surface Water Discharge Rates

Development shall not commence until a scheme restricting the rate of treated surface water discharge from the site to a maximum of *5 litres per second per hectare or 3 litres per second, whichever is the higher*, has been submitted to and approved in writing by Local Planning Authority. The excavated area shall provide attenuation in the first instance. The scheme shall include a detailed operation and maintenance/management regime for the treatment facility including the flow restriction. The approved maintenance and management scheme shall be implemented throughout the lifetime of the proposed works.

Advice Note

Any settlement of solids is a treatment of waste water and appropriate licence agreements should be sought from the Environment Agency.

