

**Consultation Response from KC,
Lead Local Flood Authority**

2023/91345 Dewsbury and District Hospital, Halifax Road, Dewsbury, WF13 4HS

Erection of single storey building with roof top plant area to provide outpatient theatres, treatment rooms and consultant rooms with link to Boothroyd building, including demolition and remodelling of existing ramp and associated landscaping and drainage

Date Responded: 12/07/2023.

Responding Officer: Martin Stephenson

Responding Ref: 1

Previous response by the LLFA

Dated 13/06/2023 for application 2023/91345

Documents reviewed by the LLFA:

Darwin Group:

- Drawing Ref: 180598-DGL-01-00-DR-A-1171, Site Logistics Plan 1, Rev P3 dated 13/06/2023.

Drainage Summary:

The submitted Site Logistics Plan allows the LLFA to remove the objection noted in the previous consultation response and will now accept the connection of the attenuated surface water discharge to the combined sewer within the site.

Note however, the comment regarding the use of a proprietary Flow Control Device (e.g. HydroBrake) instead of the proposed 100mm diameter pipe laid at a slack gradient to restrict the off-site discharge rate. The Flow Control Device should be rated at **12.4 l/s** as stated in the Drainage Statement in Table 5.3.

The suggested Drainage Planning Conditions, as noted in the previous consultation response, are still applicable.