

Consultation Response from KC, Lead Local Flood Authority
2023/91431 land south of, The Lodge and north of Church Lane, Linthwaite, Huddersfield
Discharge of conditions 7 (internal roads), 8 (Church Lane crossing), 12 (electric vehicle charging), 13 (waste storage and collection), 17 (attenuation basin), 18 (flood routing), 23 (crime prevention) and 32 (landscaping) of previous permission 2021/91571 for erection of residential development for 125 dwellings
Date Responded: 15th July 2023 Responding Officer: Paul Farndale Responding Ref:

Condition 23 – Flood Routing

Swales for flood routing of cascading water from grassed slopes are now included on landscaped drawings.

We can recommend that this condition can be discharged.