

Consultation Response from KC, Lead Local Flood Authority
2023/91441 31, Chapel Hill, Linthwaite, Huddersfield, HD7 5NJ
Change of use and alterations to former church (B8-storage) to 9 residential units (C3) and formation of car park (Listed Building within a Conservation Area)
Date Responded: 22/08/2025. Responding Officer: Martin Stephenson Responding Ref: 1
<u>Previous response by the LLFA</u> Dated 16/06/2023 for application 2023/91441 <u>Documents reviewed by the LLFA:</u> Dudley Consulting Engineers: <ul style="list-style-type: none">• 23345-XX-XX-XX-DR-100, Raised Deck Car Park Floor, Rev P02 dated 22/05/2025. <u>Drainage Summary:</u> As noted in the LLFA's response dated 16/06/2023, the drained area of the site remains the same following the refurbishment of the existing building so there is no increase in flood risk and therefore the LLFA does not require attenuation of surface water discharge. The other comments noted in the LLFA's response dated 16/06/2023 are still relevant. Regarding the Raised Deck Car Park Floor drawing, the LLFA would prefer the developer to provide several drainage points through the floor slab such that there is not a concentration of surface water run-off at the edge of the slab which could result in scouring of the natural ground surface below. Kirklees Flood Management & Drainage as Lead Local Flood Authority SUPPORTS this application SUBJECT to the comments above and has no recommended drainage conditions