

Consultation Response from: KC Environmental Health (Pollution & Noise Control)		
2023/91483 adj, 33a, Church Lane, Clayton West, Huddersfield, HD8 9LY		
Demolition of garage and erection of detached dwelling		
Date Responded: 5th July 2023	Responding Officer: RM	Responding Ref: WK/202318967
We have reviewed the application and supporting information and make the following comments and recommendations. Contaminated Land A Coal Mining Risk Assessment by Rogers Environmental Geotechnical Specialists (ref: J3596/16/EDS) (dated: August 2016) has been submitted in support of the application. The report concludes that there is the potential for shallow coal workings beneath the site and recommends further investigation to determine the presence of such workings. Part of the proposed development site is currently occupied by a single timber and asbestos structure comprising of 4 garages and unused allotment gardens. Due to the potential of shallow coal workings beneath the site and the use of the garages for storage of oils and paints etc in addition to asbestos, ground contamination will need to be considered. Therefore, it is necessary for contaminated land conditions. Loss of amenity caused by the construction of the development There is a potential for loss of amenity to the occupiers of nearby properties from noise and vibration from the construction phase of the development. Therefore, it is necessary for a condition restricting the times when noisy construction activities (including deliveries) will be permitted. Electric Vehicle Charging Points (EVCP) In an application of this nature, it is expected that facilities for charging electric vehicles and other ultra-low emission vehicles are provided in accordance with the National Planning Policy Framework and <i>Air Quality & Emissions Technical Planning Guidance</i> from the West Yorkshire Low Emissions Strategy Group. A condition requiring charging points is therefore necessary. <u>Recommended Conditions</u> CLC1 Submission of a Phase 1 Preliminary Risk Assessment Report - Condition Groundworks shall not commence until actual or potential land contamination at the site has been investigated and a Preliminary Risk Assessment (Phase I Desk Study Report) by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority. Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 183 and 184 of the National Planning Policy Framework CLC2 Submission of a Phase 2 Intrusive Site Investigation Report - Condition Where further intrusive investigation is recommended in the Preliminary Risk Assessment		

approved pursuant to condition (CLC1) groundworks (other than those required for a site investigation report) shall not commence until a Phase II Intrusive Site Investigation Report by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 183 and 184 of the National Planning Policy Framework

CLC3 Submission of Remediation Strategy - Condition

Where site remediation is recommended in the Phase II Intrusive Site Investigation Report approved pursuant to condition (CLC2) further groundworks shall not commence until a Remediation Strategy by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 183 and 184 of the National Planning Policy Framework

CLC4 Implementation of the Remediation Strategy - Condition

Remediation of the site shall be carried out and completed in accordance with the Remediation Strategy approved pursuant to condition (CLC3). In the event that remediation is unable to proceed in accordance with the approved Remediation Strategy or contamination not previously considered in either the Preliminary Risk Assessment or the Phase II Intrusive Site Investigation Report is identified or encountered on site, all groundworks in the affected area (except for site investigation works) shall cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Works shall not recommence until proposed revisions to the Remediation Strategy have been submitted to and approved in writing by the Local Planning Authority. Remediation of the site shall thereafter be carried out in accordance with the approved revised Remediation Strategy.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 183 and 184 of the National Planning Policy Framework

CLC5 Submission of Verification Report - Condition

Following completion of any measures identified in the approved Remediation Strategy or any approved revised Remediation Strategy a Verification Report by a suitably competent person shall be submitted to the Local Planning Authority. No part of the site shall be brought into use until such time as the remediation measures have been completed for (that part of) the site in accordance with the approved Remediation Strategy or the approved revised Remediation Strategy and a Verification Report in respect of those remediation measures has been approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 183 and 184 of the National Planning Policy Framework

CLC7 Contaminated land - Footnote

All contamination reports shall be prepared by a suitably competent person, as defined in Annex 2 of the National Planning Policy Framework 2021. Reports must be prepared in accordance with the following guidance:

- *Land Contamination Risk Management (LCRM)*
- BS 10175:2011+ A2:2017 *Investigation of Potentially Contaminated Sites. Code of Practice*
- *Development on Land Affected by Contamination - Technical Guidance for Developers, Landowners & Consultants - (v11.2) June 2020* by the Yorkshire and Lincolnshire Pollution Advisory Group.

The conditions relate to Planning Control only. Approval under the Building Regulations may also be required, and the applicant should contact their Building Control Provider for further information. Any other necessary consent must be obtained from the appropriate authority. If the applicant commences work without discharging conditions, they will be at risk of enforcement action and invalidating the permission if the planning condition is a pre commencement condition.

CSC1 Construction Site Working Times - Condition

No construction related noise shall be audible beyond the site boundary outside the hours of:
07.30 to 18.30 hours Mondays to Fridays

08.00 to 13.00 hours, Saturdays

With no construction related noise audible beyond the site boundary on Sundays or Public Holidays.

Reason: To safeguard the amenities of the occupiers of nearby properties in accordance with part 15 of the NPPF and LP52 of the Local Plan

CSF1 Construction Sites working times – Footnote

Kirklees Council has powers under Section 60 of the Control of Pollution Act 1974 to control noise from construction sites and may serve a notice imposing requirements on the way in which construction works are to be carried out. It has additional powers under Sections 80 of the Environmental Protection Act 1990 to prevent statutory nuisance including noise, dust, smoke and artificial light and must serve an abatement notice when it is satisfied that a statutory nuisance exists or is likely to occur or recur. Failure to comply with a notice served using the above-mentioned legislation would be an offence for which the maximum fine on summary conviction is unlimited.

EVC1 Electric Vehicle Charging Points - Condition

Before first occupation, a scheme detailing the dedicated facilities that will be provided at the dwelling for charging electric vehicles and other ultra-low emission vehicles shall be submitted to and approved in writing by the Local Planning Authority. The scheme shall meet the requirements of the current West Yorkshire Low Emission Strategy (WYLES) document. The approved dedicated facilities for charging electric vehicles shall be installed prior to occupation and retained for use thereafter.

Reason: In the interest of supporting and encouraging low emission vehicles, in the interest of air quality enhancement, to comply with the aims and objectives of Policies LP20, LP24 and LP47 of the Kirklees Local Plan, Chapters 2, 9 and 15 of the National Planning Policy Framework and the West Yorkshire Low Emission Strategy (WYLES).

EVF1 Electric Vehicle Charging Points – Footnote

- The electrical supply of the final installation should allow the charging equipment to operate at full rated capacity and the installation must comply with all applicable electrical requirements in force at the time of installation.
- The conditions relate to Planning Control only. Approval under the Building Regulations

may also be required, and the applicant should contact their Building Control Provider for further information in relation to Approved Document S.