Kirklees COUNCIL

Consultation Response from: KC Environmental Health (Pollution & Noise Control)		
2023/91528 Huddersfield Royal Infirmary, Acre Street, Lindley, Huddersfield, HD3 3EA		
Discharge conditions 11 (cycle parking), 12 (landscape strategy), 14 (car park management plan), 15 (barrier details), 20 (electric charging points) on previous permission 2021/92488 for erection of clinical building to accommodate new accident and emergency department, associated vehicular access, car and cycle parking spaces, plant and landscaping		
Date Responded: **12th July 2023**	**Responding Officer:** **RM**	**Responding Ref:** **WK/202319889**

The following comment relates to Condition 20 only which is within the remit of Environmental Health.

Condition 20 (electric charging points)
To discharge condition 20 the following information has been submitted:

- MER – Commercial EV Charging supply + Commissioning Guide for Contractors
- Eve Double Pro-line Technical Installation Manual
- Survey Report – Back Area 2 x 22Kw Duals and 1 x 22Kw Single
- Drawing no. (HG0052-IBI-ED-XX-PL-L-700001 C09) (dated: 18/04/2021) External Works General Arrangement Plan.
- Drawing no. (HG0052-IBI-ED-XX-PL-L-700002 C07) (dated:09/06/2022) Kerb Setting Out

The proposal is to install 2 x 22Kw Dual Alfen Post mounted EV chargers, and 1 x 22Kw single Alfen Post mounted EV charger. These will take up 5 parking bays allowing 5 vehicles to be charged simultaneously.

We accept the information that has been submitted and make the following recommendation.

Recommendation
Condition 20 (electric charging points)
We accept the information that has been submitted to discharge condition 20 but cannot recommend that the condition is fully discharged until the electric vehicle charging points have been installed in accordance with the submitted information as detailed above and are fully operational.