

**Consultation Response from: KC Environmental Health (Pollution & Noise Control)**

**2023/91571 Unit M Junction 27 Retail Park, Holden Ing Way, Birstall, Batley, WF17 9AD**

**Advertisement Consent for erection of illuminated signs**

**Responding Date:**  
29<sup>th</sup> June 2023

**Responding Officer:**  
SR

**Responding Ref:**  
WK202318608

**Comments**

We have reviewed application 2023/91571 for the erection of three internally illuminated signs and one internally illuminated roundel and make the following comments and recommendations which are within the remit of Environmental Health.

The application form gives the dimensions of the three fascia signs, which are all less than 10m<sup>2</sup>, the luminance level of these signs is given as 500cd/m<sup>2</sup>. This is below the maximum level set in The Institute of Lighting Professionals PLG05 document, Table 4.

We accept the information and have no objections to permission being granted for this development.