

Nina Sayers
Kirklees Metropolitan Borough Council
Development Management

Our ref: RA/2023/146428/01-L01
Your ref: 2023/91658

Date: 10 November 2023

By email: dc.admin@kirklees.gov.uk

Dear Nina

ERECTION OF TWO-STOREY COMMERCIAL/OFFICE UNIT – 260, BRADFORD ROAD, BATLEY, WF17 6JD

Thank you for consulting us on this application which we received on 27 October 2023. We note that the development is located within Flood Zone 2 and also within 20m of Batley Beck which is designated as a main river. We have no concerns with the proposal and have the following advice for the LPA and applicant.

Flood risk standing advice – advice to LPA

The proposed development falls within Flood Zone 2, which is land defined in the [planning practice guidance](#) as being at risk of flooding.

We have produced a series of standard comments for local planning authorities and planning applicants to refer to on 'lower risk' development proposals. These comments replace direct case-by-case consultation with us in relation to flood risk. This proposal falls within this category.

These standard comments are known as Flood Risk Standing Advice (FRSA). They can be viewed at <https://www.gov.uk/guidance/flood-risk-assessment-for-planning-applications#when-to-follow-standing-advice>.

We recommend that you view our standing advice in full before making a decision on this application.

Environmental permit - advice to applicant

The Environmental Permitting (England and Wales) Regulations 2016 require a permit to be obtained for any activities which will take place:

- on or within 8 metres of a main river (16 metres if tidal)
- on or within 8 metres of a flood defence structure or culverted main river (16 metres if tidal)
- on or within 16 metres of a sea defence
- involving quarrying or excavation within 16 metres of any main river, flood defence (including a remote defence) or culvert
- in the floodplain of a main river if the activity could affect flood flow or storage and potential impacts are not controlled by a planning permission

For further guidance please visit <https://www.gov.uk/guidance/flood-risk-activities-environmental-permits> or contact our National Customer Contact Centre on 03708 506 506. The applicant should not assume that a permit will automatically be forthcoming once planning permission has been granted, and we advise them to consult with us at the earliest opportunity.

Should you require any further information or clarification, please contact me.

Yours sincerely

Bev Lambert
Sustainable Places - Planning Advisor

Telephone 020 3025 7982

Mobile 07833 234623

Direct e-mail bev.lambert@environment-agency.gov.uk

Team e-mail sp-yorkshire@environment-agency.gov.uk