Consultation Response from: KC Environmental Health (Pollution & Noise Control)		
2023/91658 - JD Sports Gym, 260 Bradford Road, Batley, WF17 6JD		
Erection of two-storey commercial/office unit		
Responding Date: **19 September 2023**	**Responding Officer:** **Mohammed Nasim**	**Responding Ref:** **WK202327653**

Comments

Contaminated Land

This site has been identified on our mapping system as potentially contaminated land due to its previous use as sewage works (our map ref 261/5). Contaminated land conditions are therefore necessary.

Recommended Conditions

CLC1 Submission of a Phase 1 Preliminary Risk Assessment Report - Condition

Groundworks shall not commence until actual or potential land contamination at the site has been investigated and a Preliminary Risk Assessment (Phase I Desk Study Report) by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 183 and 184 of the National Planning Policy Framework

CLC2 Submission of a Phase 2 Intrusive Site Investigation Report - Condition

Where further intrusive investigation is recommended in the Preliminary Risk Assessment approved pursuant to condition (CLC1), groundworks (other than those required for a site investigation report) shall not commence until a Phase II Intrusive Site Investigation Report by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 183 and 184 of the National Planning Policy Framework

CLC3 Submission of Remediation Strategy - Condition

Where site remediation is recommended in the Phase II Intrusive Site Investigation Report approved pursuant to condition (CLC2) further groundworks shall not commence until a Remediation Strategy by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 183 and 184 of the National Planning Policy Framework

CLC4 Implementation of the Remediation Strategy - Condition

Remediation of the site shall be carried out and completed in accordance with the Remediation Strategy approved pursuant to condition (CLC3). In the event that remediation

is unable to proceed in accordance with the approved Remediation Strategy or contamination not previously considered [in either the Preliminary Risk Assessment or the Phase II Intrusive Site Investigation Report] is identified or encountered on site, all groundworks in the affected area (except for site investigation works) shall cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Works shall not recommence until proposed revisions to the Remediation Strategy have been submitted to and approved in writing by the Local Planning Authority. Remediation of the site shall thereafter be carried out in accordance with the approved revised Remediation Strategy.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 183 and 184 of the National Planning Policy Framework

CLC5 Submission of Verification Report - Condition

Following completion of any measures identified in the approved Remediation Strategy or any approved revised Remediation Strategy a Verification Report by a suitably competent person shall be submitted to the Local Planning Authority. No part of the site shall be brought into use until such time as the remediation measures have been completed for (that part of) the site in accordance with the approved Remediation Strategy or the approved revised Remediation Strategy and a Verification Report in respect of those remediation measures has been approved in writing by the Local Planning Authority. Where verification has been submitted and approved in stages for different areas of the whole site, a Final Verification Summary Report shall be submitted to and approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 183 and 184 of the National Planning Policy Framework

CLC7 Contaminated land - Footnote

All contamination reports shall be prepared by a suitably competent person, as defined in Annex 2 of the National Planning Policy Framework 2021. Reports must be prepared in accordance with the following guidance:

- *Land Contamination Risk Management (LCRM)*
- BS 10175:2011+ A2:2017 *Investigation of Potentially Contaminated Sites. Code of Practice*
- *Development on Land Affected by Contamination - Technical Guidance for Developers, Landowners & Consultants - (v11.2) June 2020* by the Yorkshire and Lincolnshire Pollution Advisory Group.

The conditions relate to Planning Control only. Approval under the Building Regulations may also be required, and the applicant should contact their Building Control Provider for further information. Any other necessary consent must be obtained from the appropriate authority. If the applicant commences work without discharging conditions, they will be at risk of enforcement action and invalidating the permission if the planning condition is a pre commencement condition.