

**Consultation Response from: KC Environmental Health (Pollution & Noise Control)**

**2023/91787 adj, 219, Raikes Lane, Birstall, Batley, WF17 9QF**

**Discharge conditions 6 (electric charging points), 11 (hedges), 13 (footpath), 15 (carpark visibility) on previous permission 2022/92359 for erection of one dwelling**

**Date Responded:**  
**4<sup>th</sup> July 2023**

**Responding Officer:**  
**RM**

**Responding Ref:**  
**WK/202318930**

The following comments relate to the discharge of condition 6 only.

**Condition 6 (electric charging points)**

To discharge condition 6 the following information has been submitted:

- Proposed site plan scale 1:100 - Proposed details & specifications for discharge of conditions to planning approval ref: 2022/62/92359/E
- Rolec EV Charging technical data sheet

The site plan shows the location of the electric vehicle charging point (EVCP) and the annotation states that it is to be a “Dual EV charger providing continuous supply at least 32A 7Kw as Details and Specifications provided as Condition 6”.

We accept the information provided and make the following recommendation.

**Recommendation**

**Condition 6 (electric charging points)**

We accept the information that has been provided but recommend that condition 6 is not fully discharged until the agreed EVCP has been installed and made operational in accordance with the above submitted information.