

Consultation Response from KC, Conservation & Design**2023/91946 5, Hill Street, Jackson Bridge, Holmfirth, HD9 1LZ****Listed Building Consent for replacement entrance door to front elevation****Date Responded: 17.8.2023****Responding Officer: Sue Brooks****Responding Ref:**

5 Hill Street is a Grade II listed mid-terraced weaver's house within a terrace of five dwellings which date to the late 18th or early 19th century. The house is constructed in hammer dressed stone with a stone slate roof, ashlar stacks and ranges of mullioned windows. It is located on a steep hillside within the village of Jackson Bridge.

The applicant proposes the replacement of the existing front door with a new hardwood door with glazed top panels.

The existing front door is not historic, and no historic fabric will be altered, and therefore its replacement will cause no harm to the significance of the listed building. The proposed door is traditional in design, with simple glazing bead details and slim double-glazed units for the vision panels.

The drip at the bottom of the door is not a traditional detail, however this is justified due to the exposed location of the property and front elevation where water ingress is an issue. This minor detail is therefore acceptable.

The Conservation and Design Team has no objections to this proposal.