Sent: 02 August 2023 17:14

Subject: RE: Attached letter from Kirklees Council regarding application number 2023/91997 at location rear of, 28, Northorpe Lane, Northorpe, Mirfield, WF14 0QN

I would like to advise that conditions 4&5 (Retaining walls and Structures) can not be discharged, as the required information has not been provided.

In addition, Condition 6 (Surface water attenuation) can only be discharged when the necessary certification for over oversize PCC manholes (ID>0.9m) and their cover slabs, as per our requirement specified in the following link https://www.kirklees.gov.uk/beta/regeneration-and-development/pdf/highways-structural-procedures.pdf is provided and accepted.

Regards

Farhad Khatibi

Bridges & Structures Manager
Structures Section
Highways and Streetscene
Kirklees Council

Highways and Streetscene | Highways Structures | PO Box 1720 | Huddersfield | HD1 6EL

☏ **External:** 01484 221000 **Internal:** 74199
Mobile: None
✉ **Email:** farhad.khatibi@kirklees.gov.uk