

Consultation Response from: KC Environmental Health (Pollution & Noise Control)

2023/92038 1 Piper Well Lane, Shepley, Huddersfield, HD8 8BA

Discharge of condition 5. (Vehicle charging point) on previous permission no. 2023/91090 for change of use and alterations to detached garage to form holiday let

Responding Date:
24th July 2023

Responding Officer:
SR

Responding Ref:
WK202321431

Comments

We have reviewed application 2023/92038 and make the following comments and recommendations.

Condition 5 Electric Vehicle Charging Points (EVCP's)

To discharge Condition 5 the applicant has stated on the application form that they intend to install a 32A (7kW) EV charging point located to the south elevation of the proposed development. No plans have been submitted clarifying the exact location.

Whilst we accept the information provided we make the following recommendation.

Recommendations

Condition 5 Electric Vehicle Charging Points (EVCP's)

We accept the information submitted but cannot recommend discharge of condition 5 until the EVCP point has been installed and fully operational.