



Comments	Pile Ø	Count
Contig Pile	600	80

Do Not Scale	
Design Review	
Design review by:	Checked by:
Residual hazards:	

- Drawing Notes**
- For General Notes read with Drawing 0151 & 0152.
 - This drawing is to be read in conjunction with all architect's drawings from which all setting out details, dimensions, levels & waterproofing should be confirmed.
 - The contractor is to check all drawings and report any discrepancies immediately.
 - All work is to be carried out in accordance with current edition of The Building Regulations and to the satisfaction of the Local Authority Building Inspector.
 - All materials & workmanship to comply with Adept Standard Specification for concrete works.
 - This drawing is to be read in conjunction with all relevant Architects & Adept drawings.
 - Nominal concrete cover to reinforcement is 40mm Unless Noted Otherwise. Cover to reinforcement in foundations cast against ground is to be 50-75mm, refer to specific drawings.
 - Concrete grade as per mix schedule/specification.
 - All projecting reinforcement bars are to be provided with proprietary plastic protective cover to prevent impalement.
 - Read with Adept Civils Drawing External Levels Phase 1 Sheet 2 of 2 Ref 02.21011-ACE-00-ZZ-DR-C-3201.
 - Concrete should have a minimum 28 day strength of 30 N/mm².
 - B denotes High Yield Type bars e.g. B10, B12 ...
 - Reinforcing steel Fy=500 N/mm².
 - Laps to reinforcement:
B10 = 450mm
B12 = 550mm
B16 = 800mm
B20 = 1000mm
B25 = 1250mm
B32 = 1600mm
Mesh = 500mm
Mesh to be provided with flying ends to allow in plane reinforcement laps.
 - Abbreviations:
NF Near Face
FF Far Face
EF Each Face
T Top
B Bottom
M Middle
CTS Cut to suit
C/C Centres
 - Concrete grade as per mix schedule/specification.
 - Provide Movement Joints in reconstructed stone facing at 6m c/c maximum or in accordance with stone manufacturer's details.
 - Read with Drawings 7022 & 7023.

21.02.24	Updated to suit NHBC comments	WRH	TH	P4
04.12.23	Capping beam changed to 1200 deep	WRH	PG	P3
10.11.23	Rvsd to Civils drg & client comments	WRH	PG	P2
10.10.23	First issue (draft for comment)	WRH	PG	P1

Date	Description	By	Chk	Rev
------	-------------	----	-----	-----

ADEPT
CIVIL AND STRUCTURAL CONSULTING ENGINEERS

Web: www.adeptcsce.com
Email: info@adeptcsce.com
Tel: 0113 239 4518

Office address: 1912 Mill, Sunny Bank Mills, Farsley, Leeds LS28 5UJ

Project: Blue Hills

Title: Boundary Retaining Wall, Plots 65-70 (1)

Client: Countryside

Scale @ A1	Initial author	Initial checker	Approver	Initial Date
As indicated	WRH	PG	PG	Oct 2023

Status	Purpose	Adopt Ref
S2	Preliminary	09.21011

Project number: 09.21011-ACE-ZZ-XX-DR-S-7021 | Originator: Volume: Level: Type: Role: Drg. No.: Rev: P4