Consultation Response from KC, Lead Local Flood Authority
2023/92221 Temple Quarry, Liley Lane, Grange Moor, Huddersfield, WF4 4EN
Discharge of conditions 6 (wheel washing facilities), 14 (surface water drainage), 36 (dust control) and 39 (gas monitoring) of previous permission 2019/93371 for variation conditions 3 and 13 and removal condition 18 on previous permission 98/93299 for mineral extraction and restoration by landfill
Date Responded: 24/08/2023. Responding Officer: Martin Stephenson Responding Ref: 1

Discharge of Drainage Conditions

- No. 14 (surface water drainage)

Documents reviewed by the LLFA:

MWP Planning:

- Document Ref: Supporting Statement, Section 3.0 – Surface Water Drainage System.
- Drawing Ref: 10179/01, Scheme of Working, Rev A dated 20/07/2023.

Drainage Summary:

The LLFA confirms acceptance that no surface water drainage system is required as stated in the Supporting Statement Section 3.0 due to the site being free draining into underlying strata with no surface run-off leaving the site, therefore Condition 14 **can be** discharged.