Consultation Response from KC,
Lead Local Flood Authority

2023/92254 Land at, Green Acres Close, Emley, Huddersfield, HD8 9RA

Discharge conditions 6 (drainge), 7 (drainge), 14 (CEMP) on previous permission 2021/93286 for reserved matters application pursuant to outline permission 2020/91215 for erection of 41 dwellings

Date Responded: 16/10/2023.
Responding Officer: Martin Stephenson
Responding Ref: 2

Previous response by the LLFA

Dated 22/02/2021 for application 2020/91215
Dated 25/08/2023 for application 2023/92254

Discharge of Drainage Conditions

- No. 6 (Foul & SW drainage)
- No. 7 (Temporary drainage)

Documents reviewed by the LLFA:

AMA:

- Document Ref: SW Network 25.5.22, Causeway Hydraulic Calculations, dated 25/05/22.

Drainage Summary:

Condition 6
The LLFA notes that the maximum discharge rate from MHS8 (hydrobrake chamber) during the critical 1 in 100 yr (+ 30% CC) is shown in the calculations as 3.8 l/s (720 minute winter) which is greater than the allowable discharge rate, however as the hydrobrake size is at its minimum diameter (75mm), the LLFA can accept the small increase in discharge rate.

Therefore Condition 6 **can be** discharged.

Condition 7 has already been discharged.