

Consultation Response from: KC Environmental Health (Pollution & Noise Control)
2023/92278 - 507A Bradford Road, Batley, WF17 8LL
Formation of two additional floors and creation of six trade counter units within existing building and external alterations to existing brick clad portal framed industrial unit (within a Conservation Area)
**Responding Date:
09 November 2023**
**Responding Officer:
Mohammed Nasim**
**Responding Ref:
WK202332652**
Comments
Noise

The site lies within an existing commercial/light industrial area facing onto Bradford Road where background noise levels are expected to be elevated. No detail is given on the use of any fixed mechanical plant and a compliance condition is recommended should this be required.

Contaminated Land

This site has been identified on our mapping system as potentially contaminated land due to its previous use as a mill and chemical works (our map ref 67/5). The submitted proposed external alterations plan from jgd dated June 2022 Ref 20832(2) shows some additional car parking which is assumed to be on hard standing. As there is no sensitive end use, a condition for encountering unexpected land contamination is recommended.

Electric Vehicle Charging Points (EVCPs)

In an application of this nature, it is expected that facilities for charging electric vehicles and other ultra-low emission vehicles are provided in accordance with the National Planning Policy Framework and Air Quality & Emissions Technical Planning Guidance from the West Yorkshire Low Emissions Strategy Group. There are a total of 18 car parking spaces proposed as shown in the submitted proposed external alterations plan from jgd dated June 2022 Ref 20832(2). Whilst the plan shows 3no. EVCPs, no technical detail is given and so a condition requiring charging points with a minimum specification is recommended.

Recommended Conditions
NC10 Noise from Fixed Plant & Equipment - Condition

The combined noise from any fixed mechanical services and external plant and equipment shall be effectively controlled so that the combined rating level of noise from all such equipment does not exceed the background sound level at any time. 'Rating level' and 'background sound level' are as defined in BS 4142:2014+A1:2019.

Reason: To ensure the proposed development does not cause harmful noise pollution within neighbouring noise sensitive locations, in the interest of amenity, to comply with the aims and objectives of Policies LP24 and LP52 of the Kirklees Local Plan and Chapters 12 and 15 of the National Planning Policy Framework.

CLC6 Reporting of Unexpected Contamination - Condition

In the event that contamination, or the presence of coal not previously identified by the developer prior to the grant of this planning permission is encountered during the development, all groundworks in the affected area (except for site investigation works) shall

cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Groundworks in the affected area shall not recommence until either (a) a Remediation Strategy by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority or (b) the Local Planning Authority has confirmed in writing that remediation measures are not required. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures. Thereafter remediation of the site shall be carried out and completed in accordance with the approved Remediation Strategy.

Following completion of any measures identified in the approved Remediation Strategy a Verification Report shall be submitted to the Local Planning Authority. No part of the site shall be brought into use until such time as that part of the site has been remediated in accordance with the approved Remediation Strategy and a Verification Report in respect of those works has been approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 183 and 184 of the National Planning Policy Framework.

CLC7 Contaminated land - Footnote

All contamination reports shall be prepared by a suitably competent person, as defined in Annex 2 of the National Planning Policy Framework 2021. Reports must be prepared in accordance with the following guidance:

- *Land Contamination Risk Management (LCRM)*
- *BS 10175:2011+ A2:2017 Investigation of Potentially Contaminated Sites. Code of Practice*
- *Development on Land Affected by Contamination - Technical Guidance for Developers, Landowners & Consultants - (v11.2) June 2020* by the Yorkshire and Lincolnshire Pollution Advisory Group.

The conditions relate to Planning Control only. Approval under the Building Regulations may also be required, and the applicant should contact their Building Control Provider for further information. Any other necessary consent must be obtained from the appropriate authority. If the applicant commences work without discharging conditions, they will be at risk of enforcement action and invalidating the permission if the planning condition is a pre commencement condition.

EVC1 Electric Vehicle Charging Points - Condition

Before the electrical system is installed, a scheme detailing the dedicated facilities that will be provided for charging electric vehicles and other ultra-low emission vehicles shall be submitted to and approved in writing by the Local Planning Authority. The scheme shall meet at least the following minimum standard for numbers and power output:

- One Standard Electric Vehicle Charging Point providing a continuous supply of at least 16A (3.5kW) for at least 10% of non-residential parking spaces
- For developments where some or all of the parking is likely to be used for shorter stay parking (30mins to 4 hours), Fast (7-23kW) or Rapid (43kW+) charging points will be more appropriate. If Fast or Rapid charging points are proposed together with restrictions on the times that vehicles are allowed to be parked at these points, then a lower number of charging points may be acceptable.

The agreed dedicated facilities for charging electric vehicles are to be installed, maintained

and retained thereafter.

Reason: In the interest of supporting and encouraging low emission vehicles, in the interest of air quality enhancement, to comply with the aims and objectives of Policies LP20, LP24 and LP47 of the Kirklees Local Plan, Chapters 2, 9 and 15 of the National Planning Policy Framework and the West Yorkshire Low Emission Strategy (WYLES).

EVF1 Electric Vehicle Charging Points – Footnote

- A Standard Electric Vehicle Charging Point is one which is capable of providing a continuous supply of at least 16A (3.5kW) and up to 32A (7kW). The higher output is more likely to be futureproof.
- At non-residential developments, the requirement for one standard electric vehicle charging point for at least 10% of parking spaces may initially be reduced to one charging point for at least 5% of parking spaces with the remainder provided at an agreed trigger point.
- For developments where some or all of the parking is likely to be used for shorter stay parking (30mins to 4 hours), Fast (7-23kW) or Rapid (43kW+) charging points will be more appropriate. If Fast or Rapid charging points are proposed together with restrictions on the times that vehicles are allowed to be parked at these points, then a lower number of charging points may be acceptable.
- The electrical supply of the final installation should allow the charging equipment to operate at full rated capacity and the installation must comply with all applicable electrical requirements in force at the time of installation.