

Site Inspection Report

New 2 storey split level dwelling.

**Land Adjacent The Coach House, 18a Abbey Road,
Shepley, Huddersfield, West Yorkshire, HD8 8EP**

W300926

Inspection Number: 1
Inspection Date: 12/05/2023
Inspected By: Dan Norris

Excavations

Excavations dug to strip foundations

Excavations inspection for new dwelling carried out 11/05/23. Met with groundworkers on site. 600mm wide strip footings taken down 1.3m into natural sandstone strata. No drains within influential distance of the footings. Trees nearby to be removed prior to concrete being poured. No contraventions noted on site.





NOTE : This inspection report is restricted to requirements covered by Building Regulations current at that time. It does not constitute evidence that the Building Regulations have been satisfied until a Completion / Final Certificate has been issued for the project. It remains the responsibility of the person carrying out the work to ensure that the work complies with the Building Regulations.