

Consultation Response from: KC Environmental Health (Pollution & Noise Control)		
2023/92747 - O Cot Farm, New Hey Road, Scammonden, Huddersfield, HD3 3FW		
Discharge conditions 3-6 (land contamination) and 8 (noise) on previous permission 2023/90180 for erection of single storey extension to building for meat processing, handling and cold storage		
Responding Date: 12 March 2024	Responding Officer: Mohammed Nasim	Responding Ref: WK202403857
<u>Comments</u> <u>Condition 8 - Noise</u> In our comments dated 23 October 2023, we highlighted a number of shortcomings with the submitted report and details. The applicant has submitted a Noise Impact Assessment Report (NIA) authored by KP Acoustics dated 26 June 2023 Ref 26674.NIA.01 RevA in response. The report considers noise from the internal operations, the construction and sound insulation and section 6 calculates the resultant breakout, concluding in a low impact to NSRs as stated in para 6.4. This is based upon a worst case scenario and is accepted. Based upon the noise levels for the vehicle deliveries as shown in table 7.1, a BS4142 assessment has been conducted and with a +3dB correction for intermittency, it concludes in a low impact to NSRs as shown in table 4.2. <u>Recommendations</u> The findings of the submitted report are accepted and we recommend the condition is discharged.		