Kirklees COUNCIL

Consultation Response from KC, Highways Development Management
2023/92814 Land Adj, 245, Heckmondwike Road, Dewsbury Moor, Dewsbury, WF13 3NF
Erection of two semi-detached dwellings
Date Responded: 7-4-2025. Responding Officer: Mark Berry. Responding Ref: 14-6SW-3.

The highways consultation response dated 16th December 2024 requested further information and amendments including.

1, Given the existing footway along Heckmondwike Road terminates at the site access, there is no footway to the application site frontage and an existing bus stop is located to the northern boundary of the site HDM would recommend that a 2.0m wide footway is shown to be provided to the full frontage of the site. A Stage 1 Road Safety Audit (RSA) will be required for the proposed access and required footway. In the first instance as far as the Road Safety Audit is concerned the applicants should provide the RSA team CVs and an Audit Brief for approval by our Highway Safety Section.

2, Bin collection points should be shown to be provided close to the site access to enable bins to be presented on collection day without either obstructing the highway or proposed shared driveway.

3, 2.4m x 43m sight lines should be shown to be provided from the site access in both directions onto Heckmondwike Road.

4, Details of gradients to the land beyond the southern boundary of the proposed shared driveway should be provided. Is vehicle restraint needed

The applicants have now provided revised plans showing bin collection points at the site entrance, 2.4m x 43m sight lines from the site access onto Heckmondwike Road and details of road gradients.

This application still however provides insufficient information. Further details ae required as follows.

1, No information is provided regarding the provision of a 2.0m wide footway to the site frontage.

2, No information is provided regarding whether vehicle restraint is needed to the southern boundary of the proposed shared driveway. Ideally cross section should be provided showing how the proposed shared driveway is to be retained.