

Mathias Franklin
Head of Planning Services
Kirklees Metropolitan District Council
P.O. Box B93
Civic Centre
Huddersfield
HD1 2JR

Yorkshire Water Services
Developer Services
Sewerage Technical Team
PO BOX 52
Bradford
BD3 7AY

Tel: 0345 120 8482

Email:
planningconsultation@yorkshirewater.co.uk

Your Ref: 2023/92966
Our Ref: Z005219

1st November 2023

Dear Sir/Madam,

Land to the rear of 271 Cliffe Lane, Gomersal, Cleckheaton - Demolition of existing dwelling and erection of 87 dwellings including formation of a new access from Cliffe Lane, landscaping, public open space and all associated infrastructure and engineering works

Thank you for consulting Yorkshire Water regarding the above proposed development. We have the following comments:

Water Supply

A water supply can be provided under the terms of the Water Industry Act, 1991.

- 1.) Due to pressure off the 4-inch main (which has been logged) off site mains laying will be required at the developers cost.
 - a.) Connection to be taken from 160mm PVC on Grove Lane (Grid ref; 420574 426316) Approx 450m of 160mm



YorkshireWater

Waste Water

If planning permission is to be granted, the following conditions should be attached in order to protect the local aquatic environment and Yorkshire Water infrastructure:

The development shall be carried out in accordance with the details shown on the submitted plan, "Drainage Strategy' 22691-C-DR 0105 (revision P2) dated 02/08/23 that has been prepared by Topping Engineers", unless otherwise agreed in writing with the Local Planning Authority.

(In the interest of satisfactory and sustainable drainage)

1.) Yorkshire Water has no objection in principle to the drainage details submitted on drawing 'Drainage Strategy' 22691-C-DR 0105 (revision P2) dated 02/08/23 that has been prepared by Topping Engineers, namely: -

- a.) The proposed separate systems of drainage on site and off site
- b.) The proposed amount of domestic foul water to be discharged to the public foul water sewer
- c.) The proposed amount of curtilage surface water to be discharged to the private drain and ultimately watercourse.
- d.) The proposed point(s) of discharge of foul and surface water to the public sewer and watercourse

2.) If the developer is looking to have new sewers included in a sewer adoption agreement with Yorkshire Water (under Section 104 of the Water Industry Act 1991), he/she should contact our Developer Services Team (telephone 03451 208 482, email: technical.sewerage@yorkshirewater.co.uk) at the earliest opportunity. Sewers intended for adoption should be designed and constructed in accordance with the WRC publication 'Code for Adoption - a design and construction guide for developers' as supplemented by Yorkshire Water's requirements.

Yours faithfully

Reuben Thornton
Developer Services Team

