



The Coal
Authority



INVESTOR IN PEOPLE



RTPI

Learning Partner

200 Lichfield Lane
Berry Hill
Mansfield
Nottinghamshire
NG18 4RG

Tel: 01623 637 119 (Planning Enquiries)

Email: planningconsultation@coal.gov.uk

Web: www.gov.uk/coalauthority

For the Attention of: Richard Gilbert – Case Officer
Kirklees Council

[By Email: DC.Admin@kirklees.gov.uk]

10 November 2023

Dear Richard

PLANNING APPLICATION: 2023/62/92966/E

Demolition of existing dwelling and erection of 87 dwellings including formation of a new access from Cliffe Lane, landscaping, public open space and all associated infrastructure and engineering works; land to the rear of 271 Cliffe Lane, Gomersal, Cleckheaton, BD19 4SB

Thank you for your consultation letter of 20 October 2023 seeking the views of the Coal Authority on the above planning application.

The Coal Authority is a non-departmental public body sponsored by the Department for Energy Security and Net Zero. As a statutory consultee, the Coal Authority has a duty to respond to planning applications and development plans in order to protect the public and the environment in mining areas.

The Coal Authority Response: Material Consideration

I have reviewed the proposals and can confirm that the site falls within the defined Development High Risk Area.

The Coal Authority records indicate that within the planning boundary there are two recorded mine entries (shafts). An untreated mine entry and its resultant zone of influence pose a significant risk not only to surface stability but also public safety. In

addition, the site is likely affected by probable shallow coalmine workings. Voids and broken ground associated with such workings can pose a risk of ground instability and may give rise to the emission of mine gases.

The applicant has obtained appropriate and up-to-date geological and mining information, as well information from the results of intrusive site investigations undertaken. This has been used to inform the Phase II Exploratory Investigation Report (13 July 2023, prepared by GeoDyne Ltd), which accompanies the planning application. From a review of the site investigations undertaken, the Report confirms that identified shallow mine workings pose a risk to ground stability, and that the two shafts, which have been located, will also require remediating.

On the basis that the development layout has clearly been designed around both of the recorded mine entries and their respective zones of influence and subject to the imposition of a planning condition to ensure the recommended remediation, the Coal Authority has no objections to this planning application.

The intrusive site investigations should be designed and undertaken by competent persons and should be appropriate to assess the ground conditions on the site in order to establish the coal-mining legacy present and the risks it may pose to the development and inform any remedial works and/or mitigation measures that may be necessary.

The applicant should note that Permission is required from the Coal Authority Permit and Licensing Team before undertaking any activity, such as ground investigation and ground works, which may disturb coal property. Please note that any comments that the Coal Authority may have made in a Planning context are without prejudice to the outcomes of a Permit application.

Mine Gas

It should be noted that wherever coal resources or coal mine features exist at shallow depth or at the surface, there is the potential for mine gases to exist. These risks should always be considered by the LPA. The Planning & Development team at the Coal Authority, in its role of statutory consultee in the planning process, only comments on gas issues if our data indicates that gas emissions have been recorded on the site. However, the absence of such a comment should not be interpreted to imply that there are no gas risks present. Whether or not specific emissions have been noted by the Coal Authority, local planning authorities should seek their own technical advice on.

SUDS

It should be noted that where SUDs are proposed as part of the development scheme consideration will need to be given to the implications of this in relation to the stability and public safety risks posed by coal mining legacy. The developer should seek their own advice from a technically competent person to ensure that a proper assessment has been made of the potential interaction between hydrology, the proposed drainage system and ground stability, including the implications this may have for any mine workings which may be present beneath the site.

The Coal Authority Recommendation to the LPA

The Coal Authority concurs with the recommendations of the Phase II Exploratory Investigation Report; that two recorded mine entries (SHAFTS) and shallow coalmine workings pose a risk to the proposed development and that remediation should be undertaken prior to development.

Accordingly, the Coal Authority recommends the imposition of the following conditions:

1. *No development shall commence (EXCLUDING DEMOLITION) until;*

a) any remediation works and/or mitigation measures to address the mine entries and the shallow mine workings, as may be necessary, have been implemented on site in full in order to ensure that the site is safe and stable for the development proposed.

The intrusive site investigations and remedial works shall be carried out in accordance with authoritative UK guidance.

2. *Prior to the occupation of the development, or it being taken into beneficial use, a signed statement or declaration prepared by a suitably competent person confirming that the site is, or has been made, safe and stable for the approved development shall be submitted to the Local Planning Authority for approval in writing. This document shall confirm the methods and findings of the intrusive site investigations and the completion of any remedial works and/or mitigation necessary to address the risks posed by the recorded mine entry.*

The Coal Authority therefore **has no objection** to the proposed development **subject to the imposition of the conditions to secure the above.** *This is our recommendation for condition wording. Whilst we appreciate that you may wish to make*

some amendment to the choice of words, we would respectfully request that the specific parameters to be satisfied are not altered by any changes that may be made.

The following statement provides the justification why the Coal Authority considers that a pre-commencement condition is required in this instance:

The undertaking of remedial measures, prior to the commencement of development, is considered to be necessary. This is in order to ensure the safety and stability of the development, in accordance with paragraphs 183 and 184 of the National Planning Policy Framework.

PLEASE INCLUDE AS INFORMATIVE NOTES FOR APPLICANTS ON ANY PLANNING PERMISSION GRANTED

1 - Ground Investigations

Under the Coal Industry Act 1994 any intrusive activities, including initial site investigation boreholes, and/or any subsequent treatment of coal mine workings/coal mine entries for ground stability purposes require the prior written permission of The Coal Authority, since such activities can have serious public health and safety implications. Failure to obtain permission to enter or disturb our property will result in the potential for court action. In the event that you are proposing to undertake such work in the Forest of Dean local authority area our permission may not be required; it is recommended that you check with us prior to commencing any works. Application forms for Coal Authority permission and further guidance can be obtained from The Coal Authority's website at: www.gov.uk/get-a-permit-to-deal-with-a-coal-mine-on-your-property

Please do not hesitate to contact me if you would like to discuss this matter further.

Yours sincerely

Chris MacArthur *B.Sc.(Hons), DipTP, MRTPI*
Planning Liaison Manager

General Information for the Applicant

Under the Coal Industry Act 1994 any intrusive activities, including initial site investigation boreholes, and/or any subsequent treatment of coal mine workings/coal mine entries for ground stability purposes require the prior written permission of The Coal Authority, since such activities can have serious public health and safety implications. Failure to obtain permission will result in trespass, with the potential for court action. In the event that you are proposing to undertake such work in the Forest of Dean local authority area our permission may not be required; it is recommended that you check with us prior to commencing any works. Application forms for Coal Authority permission and further guidance can be obtained from The Coal Authority's website at:

<https://www.gov.uk/get-a-permit-to-deal-with-a-coal-mine-on-your-property>

Building over or within the influencing distance of a mine entry (shaft or adit) can be dangerous and has the potential for significant risks to both the development and the occupiers if not undertaken appropriately. The Coal Authority would draw your attention to our adopted policy regarding new development and mine entries:

<https://www.gov.uk/government/publications/building-on-or-within-the-influencing-distance-of-mine-entries>

Disclaimer

The above consultation response is provided by The Coal Authority as a Statutory Consultee and is based upon the latest available data on the date of the response, and electronic consultation records held by The Coal Authority since 1 April 2013. The comments made are also based upon only the information provided to The Coal Authority by the Local Planning Authority and/or has been published on the Council's website for consultation purposes in relation to this specific planning application. The views and conclusions contained in this response may be subject to review and amendment by The Coal Authority if additional or new data/information (such as a revised Coal Mining Risk Assessment) is provided by the Local Planning Authority or the Applicant for consultation purposes.

In formulating this response The Coal Authority has taken full account of the professional conclusions reached by the competent person who has prepared the Coal Mining Risk Assessment or other similar report. In the event that any future claim for liability arises in relation to this development The Coal Authority will take full account of the views, conclusions and mitigation previously expressed by the professional advisers for this development in relation to ground conditions and the acceptability of development.

