

<b>Consultation Response from: KC Environmental Health (Pollution &amp; Noise Control)</b>		
<b>2023/93097 Land adjacent to, 196 Wakefield Road, Earlsheaton, Dewsbury, WF12 8AH</b>		
<b>Erection of 5 dwellings (class C3) and ancillary office accommodation, formation of associated access, car parking and landscaping</b>		
<b>Responding Date:</b> 16 <sup>th</sup> November 2023	<b>Responding Officer:</b> SR	<b>Responding Ref:</b> WK202335213
<p><b><u>Comments</u></b>          We have reviewed application 2023/93097 and make the following comments and recommendations.</p> <p><b><u>Air Quality and Noise</u></b>          We note the Design and access Statement by N L Jones Planning, dated October 2023 confirms that an Air quality impact assessment and a noise assessment are to follow. Whilst we have no objections to the proposal, the location is on a road of concern for heavy traffic flow, thus in the absence of these documents we have no alternative than to recommend conditions to ensure submission, as the assessments may require design modifications the applicant is advised to submit these as soon as possible.</p> <p><b><u>Contaminated Land</u></b>          This site has been identified on our mapping system as potentially contaminated land due to its proximity to a former colliery (Site 87/6). Coal legacy can give rise to risks from mine gases and spontaneous combustion as such contaminated land conditions are necessary.</p> <p><b><u>Construction Noise</u></b>          We acknowledge some controls listed in the Design and access Statement by N L Jones Planning, dated October 2023. Construction noise can give rise to loss of amenity to neighbouring noise sensitive receptors, for this reason a condition is necessary to limit the hours of operation for the site.</p> <p><b><u>Electric Vehicle Charging Points (EVCP's)</u></b>          In an application of this nature, it is expected that facilities for charging electric vehicles and other ultra-low emission vehicles are provided in accordance with the National Planning Policy Framework and Air Quality &amp; Emissions Technical Planning Guidance from the West Yorkshire Low Emissions Strategy Group. The Design and access Statement by N L Jones Planning, dated October 2023 informs EVCP provision will be included with the application. We are unable to find details of the provision therefore recommend a condition.</p>		
<p><b><u>Recommended Conditions</u></b></p> <p><b>AQIAC2 Air Quality Impact Assessment – New receptors in area of poor AQ – Condition</b>          Before commencement of the development a full Air Quality Impact Assessment shall be submitted to and approved in writing by the Local Planning Authority. The assessment shall determine the impact that the poor air quality in the area will have on the future occupiers of the proposed development and provide details of the required mitigation measures that will be</p>		

provided to address any such adverse impact.

**Reason:** For promoting sustainable development and transport and conserving the natural environment in accordance with parts 2, 9 & 15 of the NPPF and LP20, LP24, LP47 of the Local Plan

#### **NC9 Noise Assessment Report and Mitigation Scheme - Condition**

Before construction work commences a report specifying the measures to be taken to protect the development from noise from all significant noise sources that are likely to affect the proposed development including road traffic and commercial premises shall be submitted to and approved in writing by the Local Planning Authority.

The report shall:

- a) Determine the existing noise climate
- b) Predict the noise climate in living rooms and gardens (daytime), bedrooms (night-time) and other habitable rooms of the development
- c) Detail the proposed attenuation/design necessary to protect the amenity of the occupants of the new residences (including ventilation if required).

The development shall not be occupied until all works specified in the approved report have been carried out in full and such works shall be thereafter retained.

**Reason:** To protect the amenity of occupiers of the proposed development from noise or disturbance from nearby noise generating premises to accord with the aims of Policies LP24 and LP52 of the Kirklees Local Plan and Chapters 12 and 15 of the National Planning Policy Framework.

#### **NF4 Competent Person - Footnote**

All noise assessments should be carried out by a competent person. The applicant may wish to contact the Association of Noise Consultants <http://www.association-of-noise-consultants.co.uk/> (020 8253 4518) or the Institute of Acoustics <http://www.ioa.org.uk> (0300 999 9675) for a list of members.

#### **CLC1 Submission of a Phase 1 Preliminary Risk Assessment Report - Condition**

Groundworks shall not commence until actual or potential land contamination at the site has been investigated and a Preliminary Risk Assessment (Phase I Desk Study Report) by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority.

**Reason:** To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 183 and 184 of the National Planning Policy Framework

#### **CLC2 Submission of a Phase 2 Intrusive Site Investigation Report - Condition**

Where further intrusive investigation is recommended in the Preliminary Risk Assessment approved pursuant to condition (CLC1) groundworks (other than those required for a site investigation report) shall not commence until a Phase II Intrusive Site Investigation Report by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority.

**Reason:** To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 183 and 184 of the National Planning Policy Framework

## Framework

### **CLC3 Submission of Remediation Strategy - Condition**

Where site remediation is recommended in the Phase II Intrusive Site Investigation Report approved pursuant to condition (CLC2) further groundworks shall not commence until a Remediation Strategy by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures.

**Reason:** To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 183 and 184 of the National Planning Policy Framework

### **CLC4 Implementation of the Remediation Strategy - Condition**

Remediation of the site shall be carried out and completed in accordance with the Remediation Strategy approved pursuant to condition (CLC3). In the event that remediation is unable to proceed in accordance with the approved Remediation Strategy or contamination not previously considered [in either the Preliminary Risk Assessment or the Phase II Intrusive Site Investigation Report] is identified or encountered on site, all groundworks in the affected area (except for site investigation works) shall cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Works shall not recommence until proposed revisions to the Remediation Strategy have been submitted to and approved in writing by the Local Planning Authority. Remediation of the site shall thereafter be carried out in accordance with the approved revised Remediation Strategy.

**Reason:** To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 183 and 184 of the National Planning Policy Framework

### **CLC5 Submission of Verification Report - Condition**

Following completion of any measures identified in the approved Remediation Strategy or any approved revised Remediation Strategy a Verification Report by a suitably competent person shall be submitted to the Local Planning Authority. No part of the site shall be brought into use until such time as the remediation measures have been completed for (that part of) the site in accordance with the approved Remediation Strategy or the approved revised Remediation Strategy and a Verification Report in respect of those remediation measures has been approved in writing by the Local Planning Authority. Where verification has been submitted and approved in stages for different areas of the whole site, a Final Verification Summary Report shall be submitted to and approved in writing by the Local Planning Authority.

**Reason:** To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 183 and 184 of the National Planning Policy Framework

### **CLC7 Contaminated land - Footnote**

All contamination reports shall be prepared by a suitably competent person, as defined in Annex 2 of the National Planning Policy Framework 2021. Reports must be prepared in accordance with the following guidance:

- *Land Contamination Risk Management (LCRM)*
- *BS 10175:2011+ A2:2017 Investigation of Potentially Contaminated Sites. Code of*

*Practice*

- *Development on Land Affected by Contamination - Technical Guidance for Developers, Landowners & Consultants - (v11.2) June 2020* by the Yorkshire and Lincolnshire Pollution Advisory Group.

The conditions relate to Planning Control only. Approval under the Building Regulations may also be required, and the applicant should contact their Building Control Provider for further information. Any other necessary consent must be obtained from the appropriate authority. If the applicant commences work without discharging conditions, they will be at risk of enforcement action and invalidating the permission if the planning condition is a pre commencement condition.

**CSC1 Construction Site Working Times - Condition**

No construction related noise shall be audible beyond the site boundary outside the hours of: 07.30 to 18.30 hours Mondays to Fridays

08.00 to 13.00 hours, Saturdays

With no construction related noise audible beyond the site boundary on Sundays or Public Holidays.

**Reason:** To safeguard the amenities of the occupiers of nearby properties in accordance with part 15 of the NPPF and LP52 of the Local Plan

**CSF1 Construction Sites working times – Footnote**

Kirklees Council has powers under Section 60 of the Control of Pollution Act 1974 to control noise from construction sites and may serve a notice imposing requirements on the way in which construction works are to be carried out. It has additional powers under Sections 80 of the Environmental Protection Act 1990 to prevent statutory nuisance including noise, dust, smoke and artificial light and must serve an abatement notice when it is satisfied that a statutory nuisance exists or is likely to occur or recur. Failure to comply with a notice served using the above-mentioned legislation would be an offence for which the maximum fine on summary conviction is unlimited.

**EVC1 Electric Vehicle Charging Points - Condition**

Before first occupation, a scheme outlining the specific facilities for charging electric vehicles and other ultra-low emission vehicles at the premises must be submitted to and approved in writing by the Local Planning Authority. This scheme must meet the minimum requirements in the current West Yorkshire Low Emission Strategy (WYLES) document. The approved facilities for charging electric vehicles must be installed before occupation and retained for use thereafter.

**Reason:** In the interest of supporting and encouraging low emission vehicles, in the interest of air quality enhancement, to comply with the aims and objectives of Policies LP20, LP24 and LP47 of the Kirklees Local Plan, Chapters 2, 9 and 15 of the National Planning Policy Framework and the West Yorkshire Low Emission Strategy (WYLES).

**EVF1 Electric Vehicle Charging Points – Footnote**

- The electrical supply of the final installation should allow the charging equipment to operate at full rated capacity and the installation must comply with all applicable electrical requirements in force at the time of installation.
- The conditions relate to Planning Control only. Approval under the Building Regulations

may also be required, and the applicant should contact their Building Control Provider for further information in relation to Approved Document S.