

**Consultation Response from KC,
Lead Local Flood Authority**

2023/93113 30, Market Street, Huddersfield, HD1 2HG

Change of use and alterations to form student living accommodation with ancillary concierge and communal facilities including roof extension and roof terrace

Date Responded: 08/02/2024.

Responding Officer: Martin Stephenson

Responding Ref: 1

Documents reviewed by the LLFA:

C49 Architecture

- Drawing Ref: various existing and proposed floor plans

Drainage Summary:

The submitted drawings indicate that there is no significant increase in drained area, therefore the proposed development will not increase flood risk.

Kirklees Flood Management and Drainage as the Lead Local Flood Authority, SUPPORTS this application and has no recommended drainage conditions.