

**Consultation Response from: KC Environmental Health (Pollution & Noise Control)**

**2023/93447 - Truckline Services Ltd, Gordons Place, Manchester Road, Linthwaite, Huddersfield, HD7 5RF**

**Prior notification for change of use from office to two dwellings**

**Responding Date:  
15 December 2023**

**Responding Officer:  
Mohammed Nasim**

**Responding Ref:  
WK202338177**

### **Comments**

#### **Noise**

The site fronts on to Manchester Road and is adjacent to commercial/light industrial use. We have concerns about the impact of noise on the amenity of the occupiers of the proposed development and so a recommendation is made for a Noise Assessment to be submitted to ensure the internal noise levels are acceptable.

#### **Contaminated Land**

This site has been identified on our mapping system as potentially contaminated land due to its previous use as works (our map ref 418/9). The proposal involves the demolition of a rear extension and a condition is recommended should any unexpected land contamination be encountered.

### **Recommended Conditions**

#### **NC9 Noise Assessment Report and Mitigation Scheme - Condition**

Before construction work commences, a report specifying the measures to be taken to protect the development from noise from all significant noise sources that are likely to affect the proposed development including road traffic/commercial premises etc. shall be submitted to and approved in writing by the Local Planning Authority. The report shall:

- a) Determine the existing noise climate
- b) Predict the noise climate in living rooms and gardens (daytime), bedrooms (night-time) and other habitable rooms of the development
- c) Detail the proposed attenuation/design necessary to protect the amenity of the occupants of the new residences (including ventilation if required).

The development shall not be occupied until all works specified in the approved report have been carried out in full and such works shall be thereafter retained.

**Reason:** To protect the amenity of occupiers of the proposed development from noise or disturbance from nearby noise generating premises to accord with the aims of Policies LP24 and LP52 of the Kirklees Local Plan and Chapters 12 and 15 of the National Planning Policy Framework.

#### **NF4 Competent Person - Footnote**

All noise assessments should be carried out by a competent person. The applicant may wish to contact the Association of Noise Consultants <http://www.association-of-noise-consultants.co.uk/> (020 8253 4518) or the Institute of Acoustics <http://www.ioa.org.uk> (0300 999 9675) for a list of members.

#### **CLC6 Reporting of Unexpected Contamination - Condition**

In the event that contamination, or the presence of coal not previously identified by the developer prior to the grant of this planning permission is encountered during the development, all works in the affected area (except for site investigation works) shall cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Works in the affected area shall not recommence until either (a) a Remediation Strategy by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority or (b) the Local Planning Authority has confirmed in writing that remediation measures are not required. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures. Thereafter remediation of the site shall be carried out and completed in accordance with the approved Remediation Strategy.

Following completion of any measures identified in the approved Remediation Strategy a Verification Report shall be submitted to the Local Planning Authority. No part of the site shall be brought into use until such time as that part of the site has been remediated in accordance with the approved Remediation Strategy and a Verification Report in respect of those works has been approved in writing by the Local Planning Authority.

**Reason:** To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 183 and 184 of the National Planning Policy Framework.

#### **CLC7 Contaminated land - Footnote**

All contamination reports shall be prepared by a suitably competent person, as defined in Annex 2 of the National Planning Policy Framework 2021. Reports must be prepared in accordance with the following guidance:

- Land Contamination Risk Management (LCRM)
- BS 10175:2011+ A2:2017 Investigation of Potentially Contaminated Sites. Code of Practice
- Development on Land Affected by Contamination - Technical Guidance for Developers, Landowners & Consultants - (v11.2) June 2020 by the Yorkshire and Lincolnshire Pollution Advisory Group.

The conditions relate to Planning Control only. Approval under the Building Regulations may also be required, and the applicant should contact their Building Control Provider for further information. Any other necessary consent must be obtained from the appropriate authority. If the applicant commences work without discharging conditions, they will be at risk of enforcement action and invalidating the permission if the planning condition is a pre commencement condition.