

Consultation Response from KC, Lead Local Flood Authority
2023/93704 land northwest of, Urban Terrace, Denby Lane, Grange Moor, Huddersfield, WF4 4EB
Erection of 12 dwellings and associated works
Date Responded: 30th December 2024 Responding Officer: Paul Farndale Responding Ref:

Further to our comments of 15th November 2024, we urgently require a meeting with the planning officer with regard to where progress has and has not been made subsequently. Our OBJECTION remains.

An altered drainage system appears to have potentially solved the issue of discharge rates above 3.5l/s but simulation wizards for a series of summer and winter rainfall events is still required.

Other aspects have not been addressed within updated documents. And obsolete documents have yet to be archived.