



THIS FORM IS FOR USE BY ELECTRICITY NETWORK OPERATORS TO ADVISE LOCAL PLANNING AUTHORITIES OF PROPOSED WORKS TO BE UNDERTAKEN WITHIN THEIR DESIGNATED AREA THAT ARE CONSIDERED TO BE EXEMPTED UNDER THE OVERHEAD LINES(EXEMPTION)(ENGLAND AND WALES) REGULATIONS 2009. LOCAL AUTHORITIES HAVE THE RIGHT TO INVOKE THE FULL SECTION 37 PROCESS UNDER THE ELECTRICITY ACT 1989 SHOULD IT BE CONSIDERED NECESSARY.

The Form should be sent in triplicate to each Local Planning Authority in whose area the proposed development would be situated.

DETAILS OF APPLICANT

Name: NORTHERN POWERGRID (YORKSHIRE) PLC

Contact person: Tom Waterworth

Address: Wayleaves
98 Aketon Road
Castleford
WF10 5DS

Telephone no:

Email:

Applicant's reference: YP30361

Date: 19/01/24

To: Planning Services Kirklees Council, Market Street, PO Box B93, Civic Centre 3, Huddersfield, HD1 2JR

Electricity Act 1989: Overhead Lines (Exemption)(England and Wales) Regulations 2009

It is proposed to undertake the following work that is considered to be exempted from the Electricity Act 1989 by falling within the Overhead Lines (Exemption)(England and Wales) Regulations 2009:

Electricity equipment reinforcements – Springhead Stud, Holmfirth

In order to improve the electricity supplies in the above area, Northern Powergrid propose to reinforce the network by rebuilding our existing low voltage network with Aerial Bunched Conductor shown coloured red on the attached area plan.

I have attached an example (from a different location) of what open wire LV conductor overhead line looks like (this is currently installed) and how it would look after the required upgrade to Ariel Bunched Conductor (ABC).

We are also proposing to convert an existing pole to a double pole to enable us to house an upgraded transformer at the location. This would address the current voltage problems that we have been encountering in the area.

As this is an existing line that is proposed for improvements this would fall under the section 37(1) Regulation 3, parts (e) and (f) exemption and stay within the limitations detailed in Regulations 4 and 5.

The nature of the work has been chosen so as to cause minimum disruption and is considered to be the most acceptable.

The Council/Authority is requested to indicate that it has no objection to the work being carried out by returning two copies of this Form with the Certificate completed and signed.

Yours faithfully

Tom Waterworth

For and on behalf of the Applicant

Applicant's ref:	YP30361	Location/scheme:	Springhead Stud, Holmfirth
------------------	---------	------------------	----------------------------



CERTIFICATE

**TO BE COMPLETED BY THE LOCAL PLANNING AUTHORITY AND
RETURNED TO THE APPLICANT ELECTRICITY NETWORK COMPANY
WITHIN SIX WEEKS OF RECEIPT**

**Planning Services Kirklees Council, Market Street, PO Box B93, Civic Centre 3,
Huddersfield, HD1 2JR**

***(i) objects/does not object for the proposed development detailed above to be
undertaken under the exemptions laid down in the Overhead Lines
(Exemption)(England and Wales) Regulations 2009**

*** (ii) wishes/does not wish the Secretary of State to consider the application using
the full section 37 process under the Electricity Act 1989**

***The reasons for requesting the full section 37 process are:**

Dated:

**Signed:
Designation
(On behalf of Kirklees Council)**

***delete as appropriate**