

Sent: 02 August 2024 12:38

Subject: FW: Attached letter from Kirklees Council regarding application number 2024/90213 at location Greenside Mill, Savile Road, Skelmanthorpe, Huddersfield, HD8 9EE

Nick

Enclosed is the response I sent you in relation to condition 7 (retaining walls), which has not been provided so far.

In addition, condition 8 also can not be discharged as the information pertaining to oversize manholes is incompatible with the Sewers for Adoption and will be liable to a formal technical approval.

Regards

Farhad Khatibi

Bridges & Structures Manager
Structures Section
Highways and Streetscene
Kirklees Council

Highways and Streetscene | Highways Structures | Civic Centre 1 | High Street | Huddersfield | HD1 2NF

☎ **External:** 01484 221000 **Internal:** 74199

Mobile: None

✉ **Email:** farhad.khatibi@kirklees.gov.uk



Sent: Monday, May 13, 2024 6:30 PM

Subject: RE: Attached letter from Kirklees Council regarding application number 2024/90213 at location Greenside Mill, Savile Road, Skelmanthorpe, Huddersfield, HD8 9EE

Hi Nick

I would like to advise that condition 7 can not be discharged as the required information including suitably scaled and dimensioned X-sectional details for proposed retaining walls and modifications to the existing walls/ embankment adjacent to Saville Road/ Marsden Street have not been submitted.

Regards

Farhad Khatibi

Bridges & Structures Manager
Structures Section
Highways and Streetscene
Kirklees Council

Highways and Streetscene | Highways Structures | Civic Centre 1 | High Street | Huddersfield | HD1 2NF

☎ **External:** 01484 221000 **Internal:** 74199

Mobile: None

✉ **Email:** farhad.khatibi@kirklees.gov.uk

