

Consultation Response from KC,  
Lead Local Flood Authority

2024/90357 Land Adj, Thewlis Lane, Crosland Hill, Huddersfield, HD4 7AB

Variation conditions 2 and 29 and removal of conditions 15 and 33 on previous permission  
2013/90793 for mineral extraction

Date Responded: 04/04/2024.

Responding Officer: Martin Stephenson

Responding Ref: 1

**Documents reviewed by the LLFA:**

Bright & Associates:

- Drawing Ref: TL1181-D6, Restoration Proposals, Version 1 dated Jan 2024.

Hafren Water:

- Document Ref: 3531/FRA, FRA & SW Drainage Strategy, Version F1 dated 16/08/2023.

**Drainage Summary:**

Records held by Kirklees Council indicate that the underlying rock is “highly compatible for infiltration”. As noted in the FRA, this is the proposed method of disposal of surface water on the site following the restoration works and infiltration will be aided by the use of swales.

The LLFA concludes that the proposed works will not increase flood risk and therefore has no objections to the scheme.

**Kirklees Flood Management and Drainage as the Lead Local Flood Authority, SUPPORTS this application and has no recommended drainage conditions.**