Sent: 01 November 2024 09:32

Subject: RE: 2024/90548 - Former Riverside Works, Honley, Holmfirth, HD9 6PW

Hi Lucy

Thank you for pointing out this anomaly as none of the site sectional details including drawing no C1098 203 Rev 1 (copy attached) show any proposed retaining walls adjacent to the highway. There would appear to be some discrepancies in the drawings provided in conjunction with this application.

In addition, the key for walls on the Treatment Layout Plan (Dwg No. 102 Rev 0) are so similar it is very difficult to establish which sectional details on the corresponding Boundary Treatment Elevation Plan (Dwg No. 103 Rev 0) they relate to? Furthermore, I know the site pretty well, which is a fairly level site so I can't see why any retaining walls adjacent to A6024 Woodhead Road would be required.

Anyway, for the avoidance of any misunderstanding the applicant will need to provide further suitably scaled and fully dimensioned X-sectional details at the interface with the adjoining highway so as to clearly establish the impact of their proposals on the highway before I can offer any additional comments.

Regards

Farhad Khatibi

Bridges & Structures Manager
Structures Section
Highways and Streetscene
Kirklees Council

Highways and Streetscene | Highways Structures | Civic Centre 1 | High Street | Huddersfield | HD1 2NF

☏ **External:** 01484 221000 **Internal:** 74199
Mobile: None
✉ **Email:** farhad.khatibi@kirklees.gov.uk