

Consultation Response from: KC Environmental Health (Pollution & Noise Control)		
2024/90882 - Land south of, Leeds Road, Mirfield, WF14 0JE		
Discharge of conditions 7 (validation report) and 26 (cycle parking/storage) of previous permission 2020/92368 for erection of 14 dwellings with garages and formation of new access road		
Date Responded: 13th May 2024	Responding Officer: NH	Responding Ref: WK/202413025
Condition 26 is outside the remit of Environmental Health. Condition 7 - Validation Report Further to our comments dated April 22nd 2024, we have received eight Geoshield Reports dated between 20/12/22 and 6/11/23. We have reviewed these documents in support of the application. The documents confirm the installation of a gas membrane and reinforced raft foundations across plots 1 to 14 in accordance with good practice guidance. The documents also verify the information presented in the Validation Report authored by Arc Environmental dated 21st March 2024 (ref: 24-095). <u>Recommendations</u> Condition 7 - Validation Report We accept the information provided to date, received in support of Condition 7 and recommend that Condition 7 is discharged.		