

RE: 2024/91007 - Discharge of conditions Yew Tree Road



Dan Heneghan <Dan@heneghanarchitecture.com>

To  William Simcock



Official



CAUTION: External email. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Dear William

23. We confirm that the access times will be as per the construction work hours.

26. We can confirm that the cable and circuitry will be of adequate size to ensure a minimum continuous current demand of 16 amp (3.7kW) for standard charge and a maximum demand of 32 amp (7kW) suitable for rapid charge per charging point