

**Consultation Response from: KC Environmental Health (Pollution & Noise Control)**

**2024/90936 - Building off Slaithwaite Gate, Scapegoat Hill, Huddersfield, HD7 4NS**

**Demolition of existing storage building and erection of new storage building**

**Responding Date:**  
**07 October 2024**

**Responding Officer:**  
**Mohammed Nasim**

**Responding Ref:**  
**WK202430723**

**Comments**

We submitted comments dated 06 March 2023 under ref 2023/90497 and these remain as do our recommended conditions (as amended) which are repeated below.

**Recommended Conditions**

**EVC1 Electric Vehicle Charging Points - Condition**

Before the electrical system is installed, a scheme detailing the dedicated facilities that will be provided for charging electric vehicles and other ultra-low emission vehicles shall be submitted to and approved in writing by the Local Planning Authority. The scheme shall meet at least the following minimum standard for numbers and power output:

- One Standard Electric Vehicle Charging Point providing a continuous supply of at least 16A (3.5kW) for at least 10% of non-residential parking spaces
- For developments where some or all of the parking is likely to be used for shorter stay parking (30mins to 4 hours) Fast (7-23kW) or Rapid (43kW+) charging points will be more appropriate. If Fast or Rapid charging points are proposed together with restrictions on the times that vehicles are allowed to be parked at these points, then a lower number of charging points may be acceptable.

The agreed dedicated facilities for charging electric vehicles are to be installed, maintained and retained thereafter.

**Reason:** In the interest of supporting and encouraging low emission vehicles, in the interest of air quality enhancement, to comply with the aims and objectives of Policies LP20, LP24 and LP47 of the Kirklees Local Plan, Chapters 2, 9 and 15 of the National Planning Policy Framework and the West Yorkshire Low Emission Strategy (WYLES).

**EVF1 Electric Vehicle Charging Points – Footnote**

A Standard Electric Vehicle Charging Point is one which is capable of providing a continuous supply of at least 16A (3.5kW) and up to 32A (7kW). The higher output is more likely to be futureproof.

The electrical supply of the final installation should allow the charging equipment to operate at full rated capacity. The installation must comply with all applicable electrical requirements in force at the time of installation.

**CLC6 Reporting of Unexpected Contamination – Condition**

If contamination, the presence of coal and/or evidence of coal workings not previously identified by the developer prior to the grant of this planning permission is encountered during the development, all works in the affected area (except for site investigation works) shall

cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Works in the affected area shall not recommence until either (a) a Remediation Strategy by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority or (b) the Local Planning Authority has confirmed in writing that remediation measures are not required. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures. Thereafter remediation of the site shall be carried out and completed in accordance with the approved Remediation Strategy.

Following completion of any measures identified in the approved Remediation Strategy a Verification Report shall be submitted to the Local Planning Authority. No part of the site shall be brought into use until such time as that part of the site has been remediated in accordance with the approved Remediation Strategy and a Verification Report in respect of those works has been approved in writing by the Local Planning Authority.

**Reason:** To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 189 and 190 of the National Planning Policy Framework.

#### **CLC7 Contaminated land - Footnote**

All contamination reports shall be prepared by a suitably competent person, as defined in Annex 2 of the National Planning Policy Framework. Reports must be prepared in accordance with the following guidance:

- *Land Contamination Risk Management (LCRM)*
- *BS 10175:2011+ A2:2017 Investigation of Potentially Contaminated Sites. Code of Practice*
- *Development on Land Affected by Contamination - Technical Guidance for Developers, Landowners & Consultants - (v11.2) June 2020 by the Yorkshire and Lincolnshire Pollution Advisory Group.*

The conditions relate to Planning Control only. Approval under the Building Regulations may also be required, and the applicant should contact their Building Control Provider for further information. Any other necessary consent must be obtained from the appropriate authority. If the applicant commences work without discharging conditions, they will be at risk of enforcement action and invalidating the permission if the planning condition is a pre commencement condition.

#### **HUC1 Hours of Use - Condition**

The premises, shall not be open for business including deliveries to or dispatches from the premises, outside the hours of:

- 0730hrs and 1830hrs Monday to Friday and
- 0800hrs to 1300hrs Saturdays.

No activities shall take place on Sundays or Bank Holidays

**Reason:** To ensure that the proposed use(s) does not give rise to the loss of amenity to nearby residential properties, by reason of noise or disturbance at unsociable hours, to accord with the aims of Policies LP24 and LP52 of the Kirklees Local Plan and Chapters 12 and 15 of

the National Planning Policy Framework.

**CSC1 Construction Site Working Times - Condition**

No construction related noise shall be audible beyond the site boundary outside the hours of:

- 07.30 to 18.30 hours Mondays to Fridays
- 08.00 to 13.00 hours Saturdays

With no construction related noise audible beyond the site boundary on Sundays or Bank/Public Holidays.

**Reason:** To safeguard the amenities of the occupiers of nearby properties in accordance with part 15 of the NPPF and LP52 of the Local Plan

**CSF1 Construction Sites working times – Footnote**

Kirklees Council has powers under Section 60 of the Control of Pollution Act 1974 to control noise from construction sites and may serve a notice imposing requirements on the way in which construction works are to be carried out. It has additional powers under Sections 80 of the Environmental Protection Act 1990 to prevent statutory nuisance including noise, dust, smoke and artificial light and must serve an abatement notice when it is satisfied that a statutory nuisance exists or is likely to occur or recur. Failure to comply with a notice served using the above-mentioned legislation would be an offence for which the maximum fine on summary conviction is unlimited.