

Consultation Response from: KC Environmental Health (Pollution & Noise Control)

2024/90964 - Klippers Gents Hair Salon, 150 Blackmoorfoot Road, Crosland Moor, Huddersfield, HD4 5RE

Discharge of details reserved by condition 1. (sound insulation) of previous permission 2023/90337 for prior notification for change of use from Class E commercial to one dwelling

Responding Date:
4 April 2024

Responding Officer:
Mohammed Nasim

Responding Ref:
WK202411595

Comments

The applicant has submitted a Sound Insulation Testing Report authored by Nova Acoustics ref NP-010967 with a test date of 03 April 2024. The testing shows the airborne sound insulation to be 52dB and 53dB $D_{nT,w} + C_{tr}$ for the measured rooms and this is accepted.

Recommendations

The submitted information is accepted and we recommend the condition is discharged.