



Key:

- PE Private wall mounted passive electric charging point
- PE Private passive electric charging pedestal
- PE Public passive electric charging pedestal with 2 charging points (pay for use)

Please note:

All vehicle charging points to have a minimum continuous current demand of 16 Amps and a maximum demand of 32 Amps



P2	Minor amends following client comments	15/04/24	KL	KL
P1	First issue for comment	10/04/24	KL	CB

Revision	Date	By	Chk

All dimensions to be verified on site, and the Architect informed of any discrepancy. All drawings and specifications should be read in conjunction with the Health and Safety Plan; all conflicts should be reported to the appointed Principal Designer.



Yorkshire Country Properties
 Phase 2
 Abbey Road, Shepley

Sheet Name: Electric vehicle charging points

Purpose of Issue: Planning Status: -

Date: 08/04/24 Checked By: CB

Drawn By: KL Scale @ A2: 1:500

Project No: 8834 Revision: P2

Drawing No: 8834-BOW-A0-00-DR-A-1022

