

**Consultation Response from KC,  
Lead Local Flood Authority**

**2024/91242 Land north east of, Shepley Road, Stocksmoor, Huddersfield, HD4 6XW**

**Erection of residential development (up to 50 dwellings) with associated access, parking,  
public open space, landscaping and infrastructure**

**Date Responded: 12/06/2024.**

**Responding Officer: Martin Stephenson.**

**Responding Ref: 1**

**Documents reviewed by the LLFA:**

AMA:

- Document Ref: 20547-FRADS-001, FRA & Drainage Strategy, Rev 0 dated April 2024

**Drainage Summary:**

The submitted FRA contains an Outline Drainage Strategy. The LLFA agrees that as the site is located within FZ1, a sequential test is not required and the Flood Risk Impacts are low. In addition, the LLFA considers infiltration into the underlying soil as not being feasible due to the steeply sloping ground to the east of the development and the risk of re-emergence of flows that could de-stabilise the slope. Therefore, the LLFA accepts the proposal to discharge attenuated surface water flows to a local unnamed watercourse to the east of the site (a tributary of Stone Wood Dike) as shown on the plan in Appendix B of the FRA.

Further the LLFA accepts that the allowable surface water discharge rate off-site shall be the equivalent GFRO rate of 6.2 l/s, controlled by a 117mm dia HydroBrake with a design head of 1.0m as set out in the FRA. It is understood that the attenuated flows will be stored in a below ground off-line geocell type tank adjacent to the outfall location.

**Kirklees Flood Management & Drainage as Lead Local Flood Authority SUPPORTS this application SUBJECT to the recommended conditions set out below.**

**Suggested Drainage Conditions:**

**DR01 Drainage Details**

Development shall not commence until a detailed design scheme detailing foul, surface water and land drainage, including agreed discharge rate of **6.2 l/s** indirectly or directly to watercourse, attenuation for the critical 1 in 100 + climate change rainfall event, attenuation construction details /design, plans and longitudinal sections, hydraulic calculations and phasing of drainage provision has been submitted to and approved in writing by the Local Planning Authority. The scheme shall include a risk assessment and method statement, in accordance with CDM Regulations 2015, for access to and into the attenuation structure, and the scheme shall include a maintenance and management plan for surface water infrastructure. No part of the development shall be occupied until such approved drainage scheme has been provided on the site to serve the development or each agreed phasing of the development and retained thereafter.

**DR07 Overland Flow Routing**

The development shall not commence until an assessment of the effects of 1 in 100 year storm events, with an additional allowance for climate change, blockage scenarios and exceedance events on drainage infrastructure and surface water run-off pre and post development between the development and the surrounding area (both upstream and downstream of the development), has been submitted to and approved in writing by the Local Planning Authority. No part of the development shall be brought into use (dwellings shall not be occupied) until the works comprising the approved scheme have been completed and such approved scheme shall be retained thereafter.

**DR10 Construction Phase Surface Water Flood Risk and Pollution prevention plan.**

Development shall not commence until a scheme, detailing temporary surface water drainage for the construction phase (after soil and vegetation/site strip) has been submitted to and approved in writing by the Local Planning Authority. The scheme shall detail:

- phasing of the development and phasing of temporary drainage provision.
- include methods of preventing silt, debris and contaminants entering existing drainage systems and watercourses and how flooding of adjacent land is prevented.
- the strategy shall include a plan showing the location of the attenuation storage and supporting calculations, which shall be based on the critical 1 in 2-year storm. It should be assumed that once the site has been stripped that the percentage run-off will be 100 %. The maximum allowable off-site discharge rate shall not exceed 2.5 litres per second per ha, unless otherwise agreed with the LLFA.

The temporary works shall be implemented in accordance with the approved scheme and phasing. No phase of the development shall be commenced until the temporary works approved for that phase have been completed. The approved temporary drainage scheme shall be retained until the approved permanent surface water drainage system is in place and functioning in accordance with written notification to the Local Planning Authority.