

Consultation Response from: KC Environmental Health (Pollution & Noise Control)

2024/91293 - Salendine Filling Station, New Hey Road, Salendine Nook, Huddersfield, HD3 3UZ

Demolition of existing sales building and erection of new sales building, installation of 3 new jet wash bays, electrical vehicle charging bays with associated infrastructure, de-link of existing forecourt canopy, and associated forecourt works

Date Responded:
17th July 2024

Responding Officer:
NH

Responding Ref:
WK/202422117

Contaminated Land

This site has been identified on our mapping system as potentially contaminated land due to its current and previous use as a petrol filling station (our map ref 107/9). Contaminated land conditions are therefore necessary.

Noise

We understand the proposed scheme is a revision of the approved permission 2023/91393. Key differences include the relocation and alteration of the covered and open jet wash bays, the relocation of the substation enclosure, new plant room location. Notably, no noise report has been provided as part of the new application. Whilst a noise report may have been approved as part of the previous permission, we would expect a new/addendum report to confirm the changes in the current application would not cause loss of amenity at neighbouring noise sensitive locations.

For these reasons, we recommend that the following noise impact assessment condition and footnote be applied to any consent granted. A condition is also recommended in relation to construction working times.

Recommended Conditions

CLC1 Submission of a Phase 1 Preliminary Risk Assessment Report - Condition

Groundworks shall not commence until actual or potential land contamination at the site has been investigated and a Preliminary Risk Assessment (Phase I Desk Study Report) by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 189 and 190 of the National Planning Policy Framework

CLC2 Submission of a Phase 2 Intrusive Site Investigation Report - Condition

Where further intrusive investigation is recommended in the Preliminary Risk Assessment approved pursuant to condition (CLC1) groundworks (other than those required for a site investigation report) shall not commence until a Phase II Intrusive Site Investigation Report by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 189 and 190 of the National Planning Policy Framework

CLC3 Submission of Remediation Strategy - Condition

Where site remediation is recommended in the Phase II Intrusive Site Investigation Report approved pursuant to condition (CLC2) further groundworks shall not commence until a Remediation Strategy by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 189 and 190 of the National Planning Policy Framework

CLC4 Implementation of the Remediation Strategy - Condition

Remediation of the site shall be carried out and completed in accordance with the Remediation Strategy approved pursuant to condition (CLC3). In the event that remediation is unable to proceed in accordance with the approved Remediation Strategy or contamination not previously considered in either the Preliminary Risk Assessment or the Phase II Intrusive Site Investigation Report is identified or encountered on site, all groundworks in the affected area (except for site investigation works) shall cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Works shall not recommence until proposed revisions to the Remediation Strategy have been submitted to and approved in writing by the Local Planning Authority. Remediation of the site shall thereafter be carried out in accordance with the approved revised Remediation Strategy.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 189 and 190 of the National Planning Policy Framework

CLC5 Submission of Verification Report - Condition

Following completion of any measures identified in the approved Remediation Strategy or any approved revised Remediation Strategy a Verification Report by a suitably competent person shall be submitted to the Local Planning Authority. No part of the site shall be brought into use until such time as the remediation measures have been completed for (that part of) the site in accordance with the approved Remediation Strategy or the approved revised Remediation Strategy and a Verification Report in respect of those remediation measures has been approved in writing by the Local Planning Authority. Where verification has been submitted and approved in stages for different areas of the whole site, a Final Verification Summary Report shall be submitted to and approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 189 and 190 of the National Planning Policy Framework

CLC7 Contaminated land - Footnote

All contamination reports shall be prepared by a suitably competent person, as defined in Annex 2 of the National Planning Policy Framework. Reports must be prepared in accordance with the following guidance:

- *Land Contamination Risk Management (LCRM)*
- *BS 10175:2011+ A2:2017 Investigation of Potentially Contaminated Sites. Code of Practice*
- *Development on Land Affected by Contamination - Technical Guidance for Developers, Landowners & Consultants - (v11.2) June 2020 by the Yorkshire and Lincolnshire Pollution Advisory Group.*

The conditions relate to Planning Control only. Approval under the Building Regulations may also be required, and the applicant should contact their Building Control Provider for further information. Any other necessary consent must be obtained from the appropriate authority. If the applicant commences work without discharging conditions, they will be at risk of enforcement action and invalidating the permission if the planning condition is a pre commencement condition.

NC8 Noise Report required for proposed noise generating use close to existing noise sensitive premises - Condition

Before construction work commences a noise assessment report by a suitably competent person shall be submitted to and approved in writing by the Local Planning Authority. The report shall include:

- a) an assessment of all noise emissions from the proposed development
- b) details of existing background and predicted future noise levels at the boundary of noise sensitive premises
- c) a written scheme of how the occupants of the above-mentioned noise sensitive premises will be protected from noise from the proposed development including details of all necessary noise attenuation

The development shall not be brought into use until all works comprised within the measures specified in the approved report have been carried out in full and such measures shall be thereafter retained.

Reason: To ensure the proposed development does not cause harmful noise pollution within neighbouring noise sensitive locations, in the interest of amenity, to comply with the aims and objectives of Policies LP24 and LP52 of the Kirklees Local Plan and Chapters 12 and 15 of the National Planning Policy Framework.

NF4 Competent Person - Footnote

All noise assessments should be carried out by a competent person. The applicant may wish to contact the Association of Noise Consultants <http://www.association-of-noise-consultants.co.uk/> (020 8253 4518) or the Institute of Acoustics <http://www.ioa.org.uk> (0300 999 9675) for a list of members.

CSC1 Construction Site Working Times - Condition

No construction related noise shall be audible beyond the site boundary outside the hours of:

- 07.30 to 18.30 hours Mondays to Fridays
- 08.00 to 13.00 hours Saturdays

With no construction related noise audible beyond the site boundary on Sundays or Bank/Public Holidays.

Reason: To safeguard the amenities of the occupiers of nearby properties in accordance with part 15 of the NPPF and LP52 of the Local Plan

CSF1 Construction Sites working times – Footnote

Kirklees Council has powers under Section 60 of the Control of Pollution Act 1974 to control noise from construction sites and may serve a notice imposing requirements on the way in which construction works are to be carried out. It has additional powers under Sections 80 of the Environmental Protection Act 1990 to prevent statutory nuisance including noise, dust, smoke and artificial light and must serve an abatement notice when it is satisfied that a

statutory nuisance exists or is likely to occur or recur. Failure to comply with a notice served using the above-mentioned legislation would be an offence for which the maximum fine on summary conviction is unlimited