

Consultation Response from: KC Environmental Health (Pollution & Noise Control)
2024/91334 Thorncliffe Grange, Thorncliffe Lane, Emley, Huddersfield, HD8 9RS
Prior notification for erection of agricultural building
Date Responded:
30th May 2024
Responding Officer:
RM
Responding Ref:
WK/202416160

The application relates to the erection of an agricultural building for the storage of winter fodder (grass silage) due to increased stock numbers and the housing of cows all year round. We have reviewed the application and make the following comments and recommendations.

Contaminated Land

According to our records the site of the proposed development is not on land which is potentially contaminated due to its former use and is not within 250m of any historic landfill sites. However, it is within a Development High Risk Area, where there is the potential for coal/historic coal workings. Therefore, we recommend conditions relating to unexpected contamination being encountered during the construction phase.

Loss of amenity caused by the construction of the development

There is a potential for loss of amenity to the occupiers of nearby properties from noise and vibration from the construction phase of the development. Therefore, we recommend a condition restricting the times when noisy construction activities (including deliveries) will be permitted.

Recommendations
CLC6 Reporting of Unexpected Contamination – Condition

If contamination, the presence of coal and/or evidence of coal workings is encountered during the development, all works in the affected area (except for site investigation works) shall cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Works in the affected area shall not recommence until either (a) a Remediation Strategy by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority or (b) the Local Planning Authority has confirmed in writing that remediation measures are not required. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures.

Thereafter remediation of the site shall be carried out and completed in accordance with the approved Remediation Strategy.

Following completion of any measures identified in the approved Remediation Strategy a Verification Report shall be submitted to the Local Planning Authority. No part of the site shall be brought into use until such time as that part of the site has been remediated in accordance with the approved Remediation Strategy and a Verification Report in respect of those works has been approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 189 and 190 of the National Planning Policy Framework.

CLC7 Contaminated land - Footnote

All contamination reports shall be prepared by a suitably competent person, as defined in Annex 2 of the National Planning Policy Framework. Reports must be prepared in accordance with the following guidance:

- *Land Contamination Risk Management (LCRM)*
- *BS 10175:2011+ A2:2017 Investigation of Potentially Contaminated Sites. Code of Practice*
- *Development on Land Affected by Contamination - Technical Guidance for Developers, Landowners & Consultants - (v11.2) June 2020 by the Yorkshire and Lincolnshire Pollution Advisory Group.*

The conditions relate to Planning Control only. Approval under the Building Regulations may also be required, and the applicant should contact their Building Control Provider for further information. Any other necessary consent must be obtained from the appropriate authority. If the applicant commences work without discharging conditions, they will be at risk of enforcement action and invalidating the permission if the planning condition is a pre commencement condition.

CSC1 Construction Site Working Times - Condition

No construction related noise shall be audible beyond the site boundary outside the hours of:

- 07.30 to 18.30 hours Mondays to Fridays
- 08.00 to 13.00 hours Saturdays

With no construction related noise audible beyond the site boundary on Sundays or Bank/Public Holidays.

Reason: To safeguard the amenities of the occupiers of nearby properties in accordance with part 15 of the NPPF and LP52 of the Local Plan

CSF1 Construction Sites working times – Footnote

Kirklees Council has powers under Section 60 of the Control of Pollution Act 1974 to control noise from construction sites and may serve a notice imposing requirements on the way in which construction works are to be carried out. It has additional powers under Sections 80 of the Environmental Protection Act 1990 to prevent statutory nuisance including noise, dust, smoke and artificial light and must serve an abatement notice when it is satisfied that a statutory nuisance exists or is likely to occur or recur. Failure to comply with a notice served using the above-mentioned legislation would be an offence for which the maximum fine on summary conviction is unlimited.