

Consultation Response from: KC Environmental Health (Pollution & Noise Control)**2024/91357 - Cummins Turbo Technology, St Andrew's Road, Huddersfield, HD1 6RA****Erection of steel frame car port with solar panels on the roof over the existing visitor car parking area and re-lining of the visitor car park****Date Responded:**
19th July 2024**Responding Officer:**
NH**Responding Ref:**
WK/202422934

We have reviewed the application and have no objections. We recommend the following advisory is applied to any consent granted.

Recommendations**Electric Vehicle Charging Points – Advisory**

We note that parking is proposed at this development. We would encourage any electric vehicle charging points installed as part of this development to meet the requirements of the *Air Quality & Emissions Technical Planning Guidance* from the West Yorkshire Low Emissions Strategy Group. The applicant should note the following:

- The electrical supply of the final installation should allow the charging equipment to operate at full rated capacity and the installation must comply with all applicable electrical requirements in force at the time of installation.
- Approval of EVCPs under the Building Regulations may also be required, and the applicant should contact their Building Control Provider for further information in relation to Approved Document S.

For further information regarding dust control, guidance can be found in the Institute of Air Quality Management (IAQM) document "*Guidance on the assessment of dust from demolition and construction*" Version 2.1 2023.