Consultation Response from KC, Trees
2024/91474 Nabbs Lane Chemical Works, Nabbs Lane, Slaithwaite, Huddersfield, HD7 5AT
Erection of 6 storage units
Date Responded: 26/09/2024 Responding Officer: JD Responding Ref: 37/95
There is a woodland TPO 37/95 protecting all surrounding trees on this site. It is difficult to tell the level of Impact on the surrounding trees as I would need further information. If the applicant can provide the information as to whether any tree works are proposed to facilitate the development and if the new retaining wall requires any ground to be broken. If the answer to both of these is no then there would be no need for an Arboricultural Impact assessment. If the new retaining wall is to simply be stacked on existing hardstanding, then there will be no disturbance to the Roots of the protected trees. There is a holding objection until the above information is clarified in writing.